



88 6th Street, Suite 400
New Westminster
British Columbia V3L 5B3

Phone: (604) 660-6286
Toll Free: 1-866-566-SAFE
Fax: (604) 660-6215
www.safetyauthority.ca

October 19, 2009

Attention: Event Organizers

Re: Temporary Electrical Entertainment Permits

Any event exceeding the following listed electrical requirements will necessitate a Temporary Electrical Entertainment Permit.

1. Use of more than three (3) electrical cords.
2. Use a generator larger than 5 KW.

Events that do not require a Temporary Entertainment Permit must still follow the listed requirements for a safe installation.

- Hard usage type flexible cord such as type S cab tire, in good condition including ground pins.
- Connect to existing 15 amp grounded receptacles.
- Position cords to prevent damage to cords and tripping hazard to the public.

Yours truly,

Bob Hirsch
Electrical Safety Officer
British Columbia Safety Authority