



NOTES

1. REFER TO CONTRACT DRAWINGS AND SECTION 34 41 13 FOR DETAILED SPECIFICATIONS.
2. ALL DIMENSIONS IN MILLIMETERS UNLESS OTHERWISE NOTED.
3. DISCONNECT AND METER CABINETS TO BE LOCATED MINIMUM 1.0m AWAY FROM ANY OTHER ELECTRICAL EQUIPMENT OR STRUCTURE.
4. INSTALL SERVICE PANEL AND METER ENCLOSURE AS PER CANADIAN ELECTRIC CODE

**STANDARD
DETAIL
DRAWING**

DATE:
04/19/21
SCALE:
NTS

**CONTROLLER SERVICE PANEL
INSTALLATION**

DWG. NO.

SS-E1.4

