



## **FIRE SAFETY PLAN FOR CONSTRUCTION, DEMOLITION AND RENOVATION**

The British Columbia Building Code 2018, Division B, Section 8.1 reference the British Columbia Fire Code (BCFC) 2018, Division B, Section 5.6 which applies to buildings, parts of buildings, and associated areas undergoing construction or demolition operations, including renovations. This Construction Fire Safety plan shall be submitted to and reviewed by the Kelowna Fire Department prior to the commencement of any construction operations.

As per BC Fire Code, Division C, 2.2.1.1 "The owner or owner's authorized agent is responsible for carrying out the provisions of the BC Fire Code", which includes establishing a work site fire safety plan.

<b>Project #:</b>	
<b>Building/Project Name:</b>	
<b>Project Address:</b>	
<b>Type of Building/Building Class</b>	
<b>Building Permit #:</b>	
<b>Building/Property Owner:</b>	
<b>Phone Number(s):</b>	
<b>Email:</b>	
<b>Project Contractor</b>	
<b>Primary Contact Person:</b>	
<b>Phone Number(s):</b>	
<b>Email:</b>	

### **EMERGENCY CONTACT INFORMATION DO NOT USE THE SAME CONTACT PHONE NUMBERS**

<b>Designate responsible for Fire Safety:</b>	
<b>24 hr Emergency Phone Number:</b>	
<b>Email address:</b>	
<b>Alternate contact person:</b>	
<b>24 hr Emergency Phone Number:</b>	



**Please check all applicable boxes or if it is not applicable identify as NA.**

- ☐ Fire hazards will be controlled in and around the building(s).
- ☐ Emergency responders will be notified of an emergency.
- ☐ Emergency responders will not be delayed in carrying out their duties safely.
- ☐ Designated supervisory staff will be appointed and organized to respond to fire emergencies and to alert all site staff.
- ☐ Staff will be instructed on confining, controlling, and extinguishing a fire.
- ☐ Instructions including schematic diagrams describing the type, location and operation of building fire emergency systems will be established.
- ☐ Building facilities, systems, equipment, and devices will be properly inspected and maintained.

**1. Emergency procedures and information needed to plan for an emergency.**

Please complete the following:

- ☐ Means of alerting site personnel of a fire will be provided. Such means shall be capable of being heard throughout the building or facility. Special means may be required for high-rise or multiple structures.
- ☐ Site personnel will be instructed on procedures following the initiation of an alarm.
- ☐ Exit routes will be clear and visible throughout the site. At least one exit not less than 1.1-meter wide will be always accessible and usable.
- ☐ In buildings being demolished, at least one stairway not less than 1.1-meter wide will be always maintained in usable condition.
- ☐ The muster point (meeting place) will be identified. Site personnel will be educated on its location.
- ☐ Personnel will be assigned to meet the fire department to give location of fire or injury.

**2. Training of site personnel on evacuation procedures**

- ☐ Site orientation will be provided.
- ☐ Regular meetings will include fire safety component.

**3. Assigned site personnel must be responsible to install and maintain fire safety duties:**

- ☐ Controlling combustibles on the site and around the buildings. i.e. pallets, garbage, waste.
- ☐ Maintaining unobstructed access routes for fire department apparatus and to fire hydrants.



- ☐ Designating and maintaining at least one exit from every floor.
- ☐ Vehicles/delivery trucks will not obstruct fire department access to the site or to adjacent buildings.
- ☐ Signs shall identify areas where “no smoking is permitted”.
- ☐ Smoking shall only be permitted 3 meters from building or part of building under construction for all multi floor C and D occupancies 6 floors or less.

#### **4. Site Identification**

- ☐ The civic address sign will be provided and visible from the street. Signage shall be written on contrasting background. (ie. Black on white)
- ☐ Signage will be provided on each floor in the primary exit each identifying the floor level and the site address for all multi floor C and D occupancies.

#### **5. Firefighting services-Hydrants, Siamese Connection, Sprinkler, Access Route”**

- ☐ Hydrants will be installed, tested, numbered and activated prior to the start of construction.
- ☐ New hydrant information will be submitted to the City of Kelowna prior to construction.
- ☐ Hydrants will be clearly identified and will be always visible.
- ☐ Firefighter access routes to the building will be provided and maintained.
- ☐ Where standpipes are required to be installed in a building under construction, the system shall be installed progressively, in conformance with the BC Building Code. The standpipe shall not be more than one floor below the highest forms.
- ☐ Where a building equipped with a standpipe system is being demolished, the standpipe system will be maintained in operable condition below two floors below the area being demolished. Fire Department to be consulted.
- ☐ Exterior signage will be provided identifying the fire department connection location. The letters “FDC” shall be posted on signage not less than 48 inches by 48 inches. Signage will be posted in close proximity to the connection and will be visible from the street.
- ☐ Firefighting services (standpipes, hydrants) will be maintained and accessible.
- ☐ Submitted drawings provided to the fire department will show the location of firefighting systems as they become operational?

#### **6. Fire Extinguishers:**

- ☐ Movable equipment (i.e. zoom boom, forklift) will be provided with a minimum 2-A:30-B:C extinguisher.
- ☐ Areas throughout the site shall be provided with 4-A:40-B:C extinguishers.
- ☐ Extinguishers will have received annual service.



- ☐ Extinguisher will be located so that the travel distance per floor will not exceed 75 feet.

#### **7. Hot Works Operations:**

- ☐ Area will be clear of flammable and combustible materials.
- ☐ A fire watch will be assigned during a hot works operation and for 60 minutes after its completion.
- ☐ A final inspection of the hot works area will be conducted 4 hours after completion.
- ☐ Will be performed by trained personnel only.
- ☐ An appropriate rated fire extinguisher will always be present.
- ☐ Appropriate ventilation will be provided.
- ☐ Hot bitumen kettles will have appropriate fire extinguishers, be operated by trained personnel and will be located away from combustible materials

#### **8. Flammable and Combustible Storage:**

- ☐ Flammable and combustible liquids will be properly stored & handled as per BCFC.
- ☐ Propane cylinders not in use will always be stored and secured outside the building.
- ☐ Compressed gases will be properly stored, handled and used in and around the building.
- ☐ Compressed Gases will not be stored within 1 meter of an exit.
- ☐ Combustible materials will be stored at least 3 meters from Compressed gas and propane.
- ☐ Propane will not be stored within 6 meters of flammable/combustible liquids.
- ☐ Propane will not be stored within 1 meter of compressed gases.
- ☐ Stored materials will be secured, vented and protected from vehicular traffic and 3 meters from egress route.
- ☐ Containers will have proper signage/placards?
- ☐ An updated list of dangerous goods (MSDS) (WHIMIS) will be maintained.

#### **9. Electrical Installations and Petroleum Gases:**

- ☐ All electrical installations, storage, and use of liquified petroleum gases will meet the requirements of the Safety Standards Act and their pursuant regulations.

#### **10. Security:**

- ☐ What kind of on-site security is provided? (locked gate, guard, etc.) \_\_\_\_\_
- ☐ Contact information for security: \_\_\_\_\_
- ☐ Site will be accessible 24 hours per day for the fire department.
- ☐ Security personnel have knowledge of their role in the site safety plan.



**11. Building Service Shut-Off, Tank Removal and Fire Separations for Demolition Sites:**

- ☐ Gas and fuel lines will be shut off and capped.
- ☐ Temporary electrical installations will be installed in conformance with the BC Safety Standards Act and pursuant regulations.
- ☐ Removal of any piping, tanks or reservoirs shall meet the requirements of the BC Fire Code, applicable Environmental regulations and a permit shall be obtained through the Kelowna Fire Department as per the Fire and Life Safety Bylaw 10760.

**12. Fire Separations in Partly Occupied Buildings**

- ☐ Where part of a building continues to be occupied, the occupied part will be separated from the part being demolished or constructed by a fire separation having a fire-resistance rating of not less than 1 hour.
- ☐ Except where a fire alarm is operational, a fire watch conducted every hour will be conducted throughout the construction/demolition site where portions of the building are occupied.

**13. Protection of Adjacent Buildings: BC Fire Code Div. B 5.6.1.2: "Protection shall be provided for buildings and facilities that could be exposed to a fire originating from this building site, parts of this building site, facilities and associated areas undergoing construction and alteration of demolition operations".**

- ☐ This site does not require protection for adjacent buildings
- ☐ This site could pose a threat to adjacent buildings. Describe protection measures:

---

---

---

---

---

---

**14. A clean building site diagram must be provided. Attach diagram at the end of this document. Copies of blueprints will not be accepted. Drawings containing information not directly related to the fire safety of this building (i.e., elevations) will not be accepted.**

- ☐ A site diagram has been provided. The onsite diagram shall include:
  - a. Muster point
  - b. Hydrant location(s)
  - c. Fire protection location
  - d. Exit paths
  - e. Service rooms
  - f. Plans for each floor area

Email Plan to: [fireprevention@kelowna.ca](mailto:fireprevention@kelowna.ca)  
Fire Prevention Officer at 250-469-8801



**THIS PAGE LEFT BLANK FOR SITE PLAN SUBMISSION**