

Bulletin: Fire Sprinkler Permits & Engineering Requirements



Bulletin # 93.04

Updated: Feb 02, 2018

Created: 1993

This bulletin is for informational purposes only. Please be sure to consult the relevant City of Kelowna bylaw.

1. Fire sprinkler permits are required for all installations and renovations, even those including only one head
2. Sealed Engineered drawings and letters of supervision are required for any job which requires hydraulic calculations. This includes all new work as well as any alterations and/or additions where there is a possibility of creating a new hydraulically remote area or where the work imposes more demand on the presently calculated area.
3. Single family residential installations of less than nine (9) heads will require a drawing and the calculations used to determine pipe sizes according to NFPA 13D (not Engineered).
4. All drawings and calculations must be submitted in duplicate for approval with the permit application.

Building & Permitting
1435 Water Street
Kelowna, BC V1Y 1J4
TEL 250-469-8960
FAX 250-862-3314