

# 2022 City of Kelowna Annual Water and Filtration Deferral Report



**Prepared for:** Interior Health and City of Kelowna

**Prepared by** Ed Hoppe, Water Quality and Customer Care Manager

City of Kelowna

951 Raymer Ave, Kelowna, BC

[www.kelowna.ca](http://www.kelowna.ca)

**Report Date Covered:** January through December 2022

**Report Date:** July 31, 2023

Table of Contents

Introduction .....1

Water System Overview.....1

    Service Area.....2

Domestic Water Source and Treatment .....3

    Domestic (Potable) Distribution System .....4

        Capital Assets .....4

        Maintenance .....5

Irrigation (non-potable) Water Source and Treatment .....6

    Reservoir and Dam Inspections.....6

    Irrigation Distribution System .....6

System Control .....7

Staffing.....7

Capital Works Projects .....9

Cross Connection Program .....11

Water Quality Monitoring .....13

    Sample Collection and Frequency.....13

    Source Water Quality Monitoring.....14

        2022 Source Water Quality Observations.....14

        Overall Lake Okanagan Water Quality Health .....14

    Treated Water Quality Monitoring .....16

        2022 Treated Water Quality Observations .....16

        Annual Physical, Chemical and Biological Analysis .....16

        Pesticides and Herbicides.....16

        Radiological .....17

    Distribution System Testing Program .....17

        2022 Distribution Water Quality Observations.....18

Filtration Deferral Requirements .....18

    Dual Disinfection .....18

    Protozoa Sampling .....19

    Source Water Protection.....19

    Drainage Water Quality Program.....20

|   |           |
|---|-----------|
| Raw Water Bacteria .....                          | 21        |
| Raw Water Physical Parameters .....               | 21        |
| <b>Water Production .....</b>                     | <b>24</b> |
| <b>Water Sustainability Management .....</b>      | <b>27</b> |
| Water Conservation .....                          | 27        |
| Landscape Water Conservation Reports (LWCR) ..... | 27        |
| Water Restrictions.....                           | 27        |
| Water Rebates.....                                | 27        |
| Eye-On-Water (EOW) .....                          | 28        |
| QWEL.....   | 28        |
| Irrigation Assessments .....                      | 28        |
| <b>Water Disruption Events .....</b>              | <b>28</b> |
| <b>Emergency Response and Notifications .....</b> | <b>29</b> |
| Water Quality Notifications .....                 | 29        |
| <b>Service Requests and Responses .....</b>       | <b>30</b> |
| <b>Long Term Improvements .....</b>               | <b>30</b> |
| <b>Conclusion .....</b>                           | <b>27</b> |
| <b>Appendix A .....</b>                           | <b>28</b> |
| <b>Appendix B .....</b>                           | <b>32</b> |
| <b>Source Water Quality Parameters .....</b>      | <b>33</b> |
| Turbidity .....                                   | 33        |
| Total Coliform.....                               | 34        |
| E. Coli.....                                      | 36        |
| pH .....  | 37        |
| Color .....                                       | 39        |
| Temperature .....                                 | 40        |
| UV Transmittance.....                             | 42        |
| Algae.....  | 43        |
| <b>Appendix C .....</b>                           | <b>45</b> |
| <b>Treated Water Quality Parameters .....</b>     | <b>46</b> |
| Turbidity .....                                   | 46        |
| Chlorine – Free .....                             | 47        |
| Total Coliform.....                               | 49        |
| E. Coli.....                                      | 49        |

pH .....50

Color .....51

Temperature .....53

UV Transmittance.....54

Annual Physical, Chemical and Biological Analysis .....56

Pesticides and Herbicides.....58

Radiological Parameters.....60

**Appendix D.....61**

**Distribution Water Quality Parameters.....62**

Chlorine – Free .....62

Total Coliform.....63

E. Coli.....63

Trihalomethanes .....64

Haloacetic Acids .....65

**Appendix E .....67**

**Drainage and Beaches .....68**

Introduction .....68

Creek Monthly Monitoring.....68

Creek Testing during elevated Turbidity at Intakes .....80

First Flush and Rain Event Monitoring at Outfalls .....84

Fascieux Creek Rain Event Sampling .....85

Beach Sampling for *E. coli* .....86

**Tributary and Beach Sampling Sites .....88**

## Introduction

As required by the *British Columbia Drinking Water Protection Act*, the City of Kelowna (COK) provides the following annual report in accordance with our conditions on permit and conditions on filtration treatment deferral.

This report provides an overview of our service area, water quality monitoring program, water sustainability initiatives, distribution system maintenance, capital works projects, cross connection program, staff certification program, water source protection activities, emergency response plan, and water services provided.

The City of Kelowna's primary focus is to provide sustainable, quality drinking water from source to tap for the customers of the Kelowna Water Utility. For further details on the content of this report or to request additional information, please contact the City of Kelowna Utility at 250-469-8502 or email [watersmart@kelowna.ca](mailto:watersmart@kelowna.ca).

## Water System Overview

The City of Kelowna water utility is one of four water providers operating within the municipal boundary and services approximately 86,000 residents. Within the water boundary, there is one main potable water distribution system that services over 99% of the population that includes the Poplar Point, Eldorado, and Cedar Creek pump stations and one small water system that services approximately 300 residents via the Swick Road pump station.




The northern industrial area of the city boundary, bordering Lake Country, is supplied with water from Okanagan Lake by the District of Lake Country Water Utility through infrastructure maintained by COK.

The Utility operates a dedicated non-potable irrigation distribution network primarily for the agricultural farming community in Southeast Kelowna in addition to some residential properties for outdoor irrigation. Water is supplied through a series of upland water reservoirs and funneled through Hydraulic Creek.



# Service Area


The defined geographical service area for Water Utility customers is bordered by Lake Okanagan to the West and three water districts to the East as presented in Figure 1.



**Figure 1.** Water Supply area for the City of Kelowna Water Utility and surrounding water districts

## Domestic Water Source and Treatment

Okanagan Lake is considered a fjord lake of glacial origin and is used as a water source by several communities in the North, Central, and South Okanagan. The lake is 135 km long, between 4-5 km in width, surface area of 348 km<sup>2</sup> and has a maximum depth of 232 meters. Major inflows primarily consist of Mission, Vernon, Trout, Penticton, Equis, Kelowna, Peachland, and Powers Creeks and is drained at the south end by the Okanagan River and continues through to a series of lake chains until it reaches its confluence with the Columbia River in the United States.



**Figure 2.** City of Kelowna Water Utility Intake locations

OK Utility is licensed to draw water from Okanagan Lake through 3 primary intakes (Poplar Point, Cedar Creek, and Swick) and 1 seasonal intake (Eldorado) that is typically only utilized during peak water demand periods. Intake locations have been designed and constructed to draw water at designated lake depths to minimize impact of suspended material, microorganisms, and chemical influences. A groundwater well (O'Reilly) is also licenced to supplement drinking water seasonally as irrigation demands increase in Southeast Kelowna.

The city water system is classified as an EOCP Level 2 water treatment system and employs a multi-barrier treatment approach that consists of UV dosing and chlorination disinfection prior to the water entering the distribution system. This aligns and complies with the “Drinking Water Treatment Objectives (Microbiological) for Surface Water Supplies in BC” as established and adopted by the Ministry of Health – Health Protection Branch.

Utilizing multiple intakes ensures that there is water source redundancy in the event that an intake needs to be taken off-line due to water quality issues in localized areas, and provides some flexibility to redirect water volume to meet demand. The Swick System remains the only independently connected intake due to the remote geographical location. Cedar Creek intake had upgrades completed in 2020 that increased the pump capacity from 15,000,000 L/day to 38,000,000 L/day (Table 1).

| Intake       | On-site Treatment | Depth to top of Intake (m) | Intake Clearance to Lake Bottom (m) | Pump Capacity (L/day) | Date Commissioned | Modifications       |
|--------------|-------------------|----------------------------|-------------------------------------|-----------------------|-------------------|---------------------|
| Poplar Point | UV, Chlorine      | 26                         | 1                                   | 75,000,000            | 1985              | UV Treatment (2005) |
| Eldorado     | UV, Chlorine      | 14                         | 0.3                                 | 25,000,000            | 1972              | UV Treatment (2005) |
| Cedar Creek  | UV, Chlorine      | 20                         | 1.5                                 | 38,000,000            | 2006              | UV Treatment (2015) |
| Swick        | UV, Chlorine      | 16                         | 1.2                                 | 1,200,000             | 1984              | UV Treatment (2005) |

**Table 1.** City of Kelowna Water Utility intake specifications

Intakes are inspected annually to ensure the integrity of the screens are maintained, intake clearance is adequate, and any buildup of material on the screens is noted and cleaned as necessary.

## Domestic (Potable) Distribution System

The Poplar Point, Cedar Creek, and Eldorado water distribution systems are classified as EOCP level IV based on population served, water storage capacity, flow, and pumping ability. The Swick distribution system is classified as a Small Water System as is the O-Reilly groundwater well system that is seasonally used to supplement water to the Hall Road area residents in Southeast Kelowna.

## Capital Assets

The COK potable distribution system consists of 5 pump stations with UV and chlorination, 2 re-chlorination stations, 19 booster stations, 26 balancing reservoirs, 48 pressure reducing stations, and delivered over 15 million cubic meters of water to customers in 2022. Over 500km of pipe make up the potable network and consists of various materials and sizes (Table 2). The Utility asset replacement program prioritizes the replacement of Cast Iron and similar type of material that was used prior to 1978. This is typically done in conjunction with road improvement projects in those areas.





| Pipe Material              | Length of Service (km) |
|----------------------------|------------------------|
| Asbestos Cement            | 150.6                  |
| Cast Iron                  | 9.4                    |
| Concrete - RCCP            | 14.0                   |
| Copper                     | 1.5                    |
| Ductile Iron               | 24.2                   |
| Galvanized                 | 0.1                    |
| High Density Polyethylene  | 13.8                   |
| PVC                        | 332.9                  |
| PVCO                       | 1.5                    |
| Steel                      | 0.3                    |
| Thermal Lined Ductile Iron | 0.7                    |
| <b>Total</b>               | <b>549</b>             |

**Table 2.** Potable Water distribution system pipe material in use

The age, condition, and value of the infrastructure assets are reviewed annually and tracked through Cityworks asset management system to ensure that sufficient funding is set aside for the repair or replacement of the assets over the lifespan.

| Asset Category             | Dimension | Replacement Value (millions) |
|----------------------------|-----------|------------------------------|
| Water main                 | 549 km    | \$555                        |
| Booster Stations           | 19        | \$16                         |
| PRV Stations               | 48        | \$55                         |
| Meters                     | 20000     | \$13                         |
| Reservoirs                 | 26        | \$63                         |
| Source Water Pump Stations | 5         | \$80                         |
| UV Reactors                | 4         | \$6                          |
| <b>Total</b>               |           | <b>\$788</b>                 |

**Table 3.** City of Kelowna Potable Water System Asset inventory value

## Maintenance

The Utility has a goal of flushing all high impact pipes and servicing all hydrants in a calendar year to reduce sediment, scaling build-up, and maintain optimum water quality. A total of 539 km of pipes were flushed (86% completed) and 2435 hydrants were serviced (99% attendance rate) in 2022. Residents may notice slight discoloration in their water after flushing, but is still considered potable. Residents are encouraged to run their taps until the water runs clear.

## Irrigation (non-potable) Water Source and Treatment

Although not part of the potable domestic water system, the Southeast Kelowna Irrigation system plays an important role in the supply of water to the Agricultural community. The water source primarily comes from a series of upland reservoirs in the Hydraulic Lake Watershed that covers approximately 140 km<sup>2</sup> and relies predominantly on snowpack for replenishing annual water supply. The reservoirs feed tributary streams that converge to supply the water intake located on Hydraulic Creek, which employs a single-barrier water treatment consisting of coarse mechanical screening and chlorine dosing. Chlorine residual will be seasonally maintained as it plays a vital role to minimize the growth of bacteria and pipe slime which can clog pipes, fittings, and coat sensor equipment. It is also necessary to maintain the City's goal of having irrigation water meet Canadian Agricultural Water Quality guidelines.



*McCulloch Reservoir*

## Reservoir and Dam Inspections


The McCulloch Reservoir system, located approximately 20 km south east of Kelowna, is a series of lakes that store water for the purpose of irrigation. Within the watershed creeks contribute water to the lakes which include dams to hold back water for over 500 irrigation customers in Southeast Kelowna. Regular inspections are carried out to monitor the integrity and performance of the dams. Monitoring and inspections are critical elements of operation that identify areas of required maintenance or improvements. In 2022 a Dam Safety Review identified conditions on the Turtle Lake Dams that require further study and remediation.

## Irrigation Distribution System

The bulk of the current irrigation distribution system was installed in the late 1960's and consists of a gravity fed intake system, 4 reservoirs, a chlorine dosing station, a debris clearing screen, 5 diversion channels, 36 pressure reducing stations, and over 50km of distribution pipe. Due to the age and technical limitations of the Irrigation water meters, a full replacement program was initiated in 2021 and completed in 2022. These have all been equipped with cellular transmitters that allow for remote meter reads on a daily basis to assess demand.

## System Control

The operation and maintenance monitoring of the water quality, operating pumps, reservoir water levels, distribution system water pressures are all conducted through the use of a Supervisory Control and Data Acquisition Software (SCADA) program. Connected by wireless links, the SCADA software remotely collects information from sensors at all of the pump stations and reservoirs and other points in the distribution system. The software interprets the receiving data and automatically adjusts pumps and system settings to maintain pre-defined operating requirements. When an issue is detected within the system, the SCADA system issues alerts and alarms to water system operators who then respond to the concerns.



## Staffing

Section 12 of the *Drinking Water Protection Regulations* (DWPR) refers to the qualification standards for water system operators. In this section, the “Environmental Operators Certification Program” (EOCP) is required for certification of operators to maintain, operate, or repair a water system. The qualification levels required for operators are determined by the class of the system under the EOCP. Current list of water system operators and certification levels are listed in Table 4, which now include Dam Inspection and Maintenance.



| Name             | Job Title                               | Water Treatment |    | Water Distribution |    |     |    | Chlorine Handling | Dam Inspection & Maintenance |
|------------------|---|-----------------|----|--------------------|----|-----|----|-------------------|------------------------------|
|                  |   | I               | II | I                  | II | III | IV |                   |                              |
| B. Stuart        | Water Supply & Pump Stations Supervisor |                 |    |                    |    |     |    |                   |                              |
| S. Saran         | Water Supply Foreman                    |                 |    |                    |    |     |    |                   |                              |
| J. Hilstob       | Water Supply Operator II                |                 |    |                    |    |     |    |                   |                              |
| D. Sharpe        | Water Supply Operator II                |                 |    |                    |    |     |    |                   |                              |
| D. Enns          | Water Supply Operator III               |                 |    |                    |    |     |    |                   |                              |
| R. Hogan         | Water Supply Operator II                |                 |    |                    |    |     |    |                   |                              |
| D. Van Asseldonk | Water Supply Operator III               |                 |    |                    |    |     |    |                   |                              |
| P. Atwood        | Water Supply Operator II                |                 |    |                    |    |     |    |                   |                              |
| T. Hall          | Water Supply Operator II                |                 |    |                    |    |     |    |                   |                              |
| D. Allingham     | Water Supply Operator II                |                 |    |                    |    |     |    |                   |                              |
| R. Day           | Electrical Foreman                      |                 |    |                    |    |     |    |                   |                              |
| S. Morane        | Instrument Technician                   |                 |    |                    |    |     |    |                   |                              |
| B. Mandryk       | Control Systems Specialist              |                 |    |                    |    |     |    |                   |                              |
| C. Jensen        | Maintenance Foreman                     |                 |    |                    |    |     |    |                   |                              |
| M. Hughes        | Water Supply Millwright                 |                 |    |                    |    |     |    |                   |                              |

| Name             | Job Title                                   | Water Distribution |    |     |    | Chlorine Handling |
|------------------|---|--------------------|----|-----|----|-------------------|
|                  |   | I                  | II | III | IV |                   |
| D. Schwarz       | Water Distribution Supervisor               |                    |    |     |    |                   |
| D. Francis       | Water Distribution Foreman                  |                    |    |     |    |                   |
| D. King          | Utility Services Person                     |                    |    |     |    |                   |
| J. Melrose       | Utility Services Person                     |                    |    |     |    |                   |
| A. Cossacchi     | Water Distribution Operator II              |                    |    |     |    |                   |
| C. Roth          | Water Distribution Operator II              |                    |    |     |    |                   |
| M. Scheidl       | Water Distribution Equipment Operator       |                    |    |     |    |                   |
| B. Callioux      | Hydrant and Valve Maintenance Attendant     |                    |    |     |    |                   |
| C. Van Steinburg | Hydrant and Valve Maintenance Attendant     |                    |    |     |    |                   |
| A. Bernardin     | Water Distribution Operator I (in training) |                    |    |     |    |                   |
| J. Daoust        | Water Distribution Operator I (in training) |                    |    |     |    |                   |

| Name            | Job Title                      | Water Distribution |    | Wastewater Collection |    |
|-----------------|--------------------------------|--------------------|----|-----------------------|----|
|                 |                                | I                  | II | I                     | II |
| M. Thomas       | Construction Manager           |                    |    |                       |    |
| J. Peterson     | Utilities Construction Foreman |                    |    |                       |    |
| C. Beitel       | Utilities Construction Foreman |                    |    |                       |    |
| L. Miles        | Utilities Construction Foreman |                    |    |                       |    |
| S. Neetz        | Utilities Construction Foreman |                    |    |                       |    |
| R. Ihaksi       | Pipelayer II                   |                    |    |                       |    |
| J. Lahn         | Pipelayer II                   |                    |    |                       |    |
| C. Saukarookoff | Pipelayer II                   |                    |    |                       |    |
| C. Fenton       | Pipelayer I                    |                    |    |                       |    |
| T. Kirbyson     | Pipelayer I                    |                    |    |                       |    |
| R. Spargot      | Pipelayer I                    |                    |    |                       |    |
| R. Wood         | Pipelayer I                    |                    |    |                       |    |
| P. Andruschak   | Equipment Operator V           |                    |    |                       |    |
| D. Bransfield   | Equipment Operator V           |                    |    |                       |    |
| P. Jamison      | Equipment Operator V           |                    |    |                       |    |
| K. Lefebvre     | Equipment Operator IV          |                    |    |                       |    |
| D. Fetterer     | Equipment Operator III         |                    |    |                       |    |
| K. Mintram      | Equipment Operator III         |                    |    |                       |    |
| B. Doig         | Hydro-Excavation Operator      |                    |    |                       |    |

**Table 4.** City of Kelowna Water System Operators certification levels



COK employs a diverse and experienced team who are responsible for managing all aspects of the Water Utility operations. This includes managers, supervisors, operators, technicians, electricians, millwrights, technical engineers, and support staff.

| Staff                        | Role   |
|------------------------------|--|
| K. Van Vliet, P.Eng., M.Eng. | Utility Services Manager   |
| M. Logan, P.Eng.             | Infrastructure General Manager                                       |
| A. Weremy, P.Eng., M. Eng.   | Water Operations Manager   |
| B. Stuart, WQT               | Water Supply and Pump Stations Supervisor. Designated Chief Operator |
| D. Schwarz, P.Ag.            | Water Distribution Supervisor  |
| B. Beach, P.Eng.             | Infrastructure Delivery Manager                                      |
| R. MacLean, P.Eng.           | Utilities Planning Manager   |
| M. Thomas                    | Construction Manager   |
| L. Thorimbert                | Communications Advisor   |
| R. MacLean, P.Eng.           | Utilities Planning Manager   |
| E. Hoppe, B.Sc., P.Chem.     | Water Quality and Customer Care Supervisor                           |
| C. Moody                     | Cross Connection Control Program Coordinator                         |
| L. Jablonski, WQT            | Water and Wastewater Quality Technician                              |
| D. Bachmann, WQT             | Water and Wastewater Quality Technician                              |

**Table 5.** City of Kelowna Water System Managers and Support Staff

## Capital Works Projects

A number of capital projects were scheduled and completed in 2022 that involved upgrades and improvements to existing water infrastructure and drainage systems that totaled over \$6.2 million. Projects were initiated and completed according to government grant funding stipulations, priority, contractor pricing, conjunction with other road construction projects, and long term development planning.



| <b>Water Capital Projects 2022</b> | <b>Description</b>                                    | <b>2022 Budget Spent</b> | <b>Level of Completion</b> |
|------------------------------------|---|--------------------------|----------------------------|
| Infrastructure Upgrade             | Hydro Excavator Parking Facility                      | \$ 77,000                | Complete                   |
| Infrastructure Upgrade             | Pressure Reducing Valve Upgrades                      | \$ 11,000                | In Progress                |
| Infrastructure Upgrade             | Water Network and Facility Renewal                    | \$ 134,000               | Ongoing Program            |
| Infrastructure Upgrade             | South End Water Upgrades (inc. SOMID Decommissioning) | \$ 1,486,000             | In Progress                |
| Infrastructure Upgrade             | Stirling PI and Keller PI Mains                       | \$ 298,000               | Complete                   |
| Infrastructure Upgrade             | Ash Rd PRV Upgrades                                   | \$ 39,000                | In Progress                |
| Infrastructure Upgrade             | Clement Ave, Ellis to Richter                         | \$ 686,000               | Complete                   |
| Infrastructure Replacement         | Raymer Avenue, Ethel to Gordon                        | \$ 71,000                | In Progress                |
| Infrastructure Upgrade             | Ellis St, Knox to Clement                             | \$ 116,000               | In Progress                |
| Infrastructure Upgrade             | Hazell Watermain Replacement                          | \$ 227,000               | In Progress                |
| Infrastructure Upgrade             | Poplar Point UV System Modifications                  | \$ 262,000               | Complete                   |
| Infrastructure Upgrade             | Skyline Pump Station Repairs and Safety Upgrades      | \$ 206,000               | Complete                   |
| Infrastructure Upgrade             | Dam Repairs - Irrigation Intake                       | \$ 69,000                | In Progress                |
| Infrastructure Replacement         | Chemical Storage Tank Replacement - KVR UV Facility   | \$ 228,000               | Complete                   |
| Infrastructure Upgrade             | McClure Watermain Relocation                          | \$ 37,000                | Complete                   |
| Infrastructure Upgrade             | Irrigation System Upgrades                            | \$ 43,000                | In Progress                |
| Infrastructure Upgrade             | Meter installations                                   | \$ 268,000               | Ongoing Program            |
| Infrastructure Replacement         | Water Meter Replacement - Stage 1                     | \$ 125,000               | Complete                   |
| Infrastructure Replacement         | Water Meter Replacement - Stage 2                     | \$ 1,755,000             | Complete                   |
| Infrastructure Upgrade             | Guy St Watermain                                      | \$ 24,000                | Complete                   |
| Infrastructure Replacement         | Hydrants  | \$ 6,000                 | Ongoing Program            |
| Infrastructure Upgrade             | Abbott ATC Watermain                                  | \$ 47,000                | Complete                   |
| <b>2022 Total Investment</b>       |   | <b>\$ 6,215,000</b>      |                            |

Table 6. Drinking Water capital projects

The new installation and replacement of water meters throughout the Kelowna Water Utility area is in year 5 of a 7-year project to ensure that all water services are equipped with current meters. The addition of cellular endpoints to all new meters allows for remote and real time access to water use data and is publicly available to residents through the use of a free, on-line download app called Eye-on-Water. The ability to have residents easily monitor and manage their water use as well as receive automated notification in the event of potential water leak, provides a critical tool to reduce water demand and waste.

## Cross Connection Program

The City of Kelowna Water Utility implemented a comprehensive Cross Connection Control (CCC) program in 1998. The CCC program is designed to protect water quality in the distribution system from backflow and any subsequent contaminants that could be carried from point of use sources. Our program has been strategically implemented to include the 4 distinct water district purveyors in Kelowna and tracked 6680 testable backflow prevention assemblies in approximately 3000 facilities throughout the city in 2022.



### Program Scope

The Cross Connection Control program applies to all water customers within the city regardless of their water purveyor. The City of Kelowna manages the program on behalf of all four major Kelowna water providers. Although the program applies to all customers, it is focused on Industrial, Commercial, Institutional, and Agricultural customers. There are standard backflow prevention requirements that apply to single family dwellings, but these requirements don't usually involve testable Back Flow Preventer (BFP) assemblies. Occasionally single family homeowners will install a commercial type of system or appliance in their home and in these instances appropriate backflow prevention assemblies may be installed. The program utilizes field inspections and review of construction plans and building permit applications to identify cross-connection hazards and risk of backflow. When a cross-connection hazard is identified, a backflow prevention assembly (BFP) is required to be installed to isolate and contain the hazard and to prevent backflow into the public water system.

### Annual Testing

Consumers connected to the public water supply in the city share the responsibility of protecting the water system from the backflow of contaminants. The assembly owners are required to contact the services of a qualified tester and submit a passing test report for the assembly(s) annually.

The City of Kelowna strives to achieve total compliance with the annual testing component of our program and is successful within 2% year after year (Table 7).

| Premise Protection                 | In-Service  | New Installs | Failures   | Cleaned   | Repairs   | Tests Completed |
|------------------------------------|-------------|--------------|------------|-----------|-----------|-----------------|
| Double Check Detector Assembly     | 15          | 2            | 1          | 0         | 0         | 18              |
| Double Check Valve Assembly        | 3094        | 218          | 114        | 12        | 12        | 3325            |
| Pressure Vacuum Breaker Assembly   | 1           | 0            | 0          | 0         | 0         | 1               |
| Reduced Pressure Backflow Assembly | 1680        | 159          | 104        | 11        | 16        | 1832            |
| <b>Total</b>                       | <b>4790</b> | <b>379</b>   | <b>219</b> | <b>23</b> | <b>28</b> | <b>5176</b>     |
| <b>Premise Isolation</b>           |             |              |            |           |           |                 |
| Double Check Detector Assembly     | 8           | 2            | 1          | 0         | 0         | 4               |
| Double Check Valve Assembly        | 1594        | 143          | 59         | 6         | 7         | 1662            |
| Reduced Pressure Backflow Assembly | 288         | 25           | 16         | 1         | 2         | 310             |
| <b>Total</b>                       | <b>1890</b> | <b>170</b>   | <b>76</b>  | <b>7</b>  | <b>9</b>  | <b>1976</b>     |
| <b>Grand Total</b>                 | <b>6680</b> | <b>549</b>   | <b>295</b> | <b>30</b> | <b>37</b> | <b>7152</b>     |

**Table 7.** Summary of 2022 Cross Connection Backflow Devices and compliance tested

## Dual Water System Protection

The Utility has taken ownership and testing responsibility of approximately 625 DCVA backflow preventors in Southeast Kelowna. These backflow preventers are a requirement to protect domestic water services installed on properties that have access to the non-potable irrigation water or are engaged in an agricultural activity.

The backflow preventers are in freeze protected pits on the public side of the property line. This is a departure from the normal cross connection control; program operation, as it is the drinking water utility protecting itself from the irrigation water utility.



## Water Quality Monitoring

The COK Water Quality Program references the following regulations and guidelines to develop a formal reporting and monitoring program:

- *Guidelines for Canadian Drinking Water Quality (GCDWQ)*
- *British Columbia Approved Water Quality Guidelines*
- *British Columbia Drinking Water Protection Act and Regulation (DWPA)*
- *Drinking Water Treatment Objectives for Surface Water in BC*
- *IHA Decision Tree for Responding to Turbidity Events in Unfiltered Water*



The *Guidelines for Canadian Drinking Water Quality* are based on the current, published scientific research related to the health effects, aesthetic effects, and operational considerations. Health based guidelines are established on the basis of comprehensive review of the known health effects associated with each contaminant, on exposure levels and on the availability of treatment and analytical techniques. The highest priority guidelines are those dealing with microbiological contaminants such as bacteria, protozoa, and viruses.

## Sample Collection and Frequency

A source to tap drinking water quality monitoring program is a function of source water quality, water treatment, and water quality through the distribution system. As a result, the monitoring of the COK drinking water quality consists of 4 main sampling and information collection components:

- Source Water Monitoring
- Monitoring at the outflow of Wastewater Treatment Plant
- Monitoring of the Pump Intakes and Distribution System
- Customer Concerns and Service Requests

The sampling location, frequency, and water quality parameters required at each of the source to tap sites are reviewed yearly, approved by IHA, and samples collected as per frequency referenced in the COK Water Utility Water Quality Sampling Guidelines ([Appendix A](#)). Qualified field and lab technicians perform more than 500 monthly tests on source and distribution water at over 80 sites throughout the system. Sampling sites include various locations from Okanagan Lake, tributary creeks, pump stations, reservoirs, booster stations, valve chambers, and final tap source points.

Data collection consists of SCADA monitoring, field measurements, in-lab testing, and submission of samples to a third party, accredited laboratory as part of the quality assurance program. Analytical results are entered into the WaterTrax software database, which has the ability to alert water operation staff and utility management in the event that specific parameters exceed operational or water quality guidelines as outlined in the CDWQG.

## Source Water Quality Monitoring

Over 2,000 combined source water samples were tested from Okanagan Lake drawn from each of the four intake locations. The samples are taken prior to both UV and Chlorine treatment and analyzed for a variety of water quality parameters either on-site at the COK laboratory or at the certified lab as per monthly sampling schedule. Detailed chemical and biological parameter descriptions, graphical trends, and related WQ objectives are listed in [Appendix B](#) and include the following:



- [Turbidity](#) (Table 11, Figures 9-10)
- [Total Coliform](#) (Table 12, Figures 11-12)
- [Escherichia coli](#) (E. Coli.) (Table 13, Figures 13-14)
- [pH](#) (Table 14, Figures 15-16)
- [Color](#) (Table 15, Figures 17-18)
- [Temperature](#) (Table 16, Figures 19-20)
- [UV Transmittance](#) (Table 17, Figures 21-22)

## 2022 Source Water Quality Observations

- Turbidity had minor exceedances above 1 NTU at intakes during June / July freshet coinciding with high Mission creek flow and turbidity conditions
- Both Total Coliform and E.coli. counts remained consistently low
- pH, algae, and yearly average temperature demonstrated an increase in concentrations
- UVT and color remained consistent year over year

## Overall Lake Okanagan Water Quality Health

In addition to internal testing program, the COK is part of an annual *Collaborative Okanagan Lake Water Quality Study* that is generated annually by Larratt Aquatic Consultants on behalf of various municipalities and districts that discharge into Okanagan Lake. This report is submitted to the Ministry of Environment as part of the condition on permit for wastewater operations. The report examines the general physical, chemical, and biological health of Lake Okanagan and water quality trends that may be influenced by tributaries as well as outfalls from treatment plants. Parameters in the Central Okanagan area generally all fell within water quality objectives published (Nordin, 2005) and accepted by the Ministry of Environment.

### Physical Properties

Okanagan Lake is usually stratified from May to November, it mixes in mid-November and then freely mixes over the winter. Secchi depth was highest in late winter and decreased each spring in response to increased phytoplankton activity. Water clarity was typical for Okanagan Lake in 2022. Only the Armstrong Arm failed to meet the Secchi depth objective in 2022, as it did in every year to date.

## Chemical Properties

Dissolved oxygen (DO) is essential for all aquatic animals and is high throughout Okanagan Lake at all times except in the hypolimnion of the Armstrong Arm where DO fell below the water quality objective each summer including 2022. Silica, an important micronutrient, had stable concentrations in Okanagan Lake over the past 20 years.

Total nitrogen (TN) exceeded the objective at all sites during 2022 as it did in most years. There were significant increasing trends in TN from 2011-2022 at Kelowna, Okanagan Centre, and Armstrong Arm, driven in part by a decades-long increasing trend in nitrate in the deep water of Okanagan Lake. This increasing nitrate trend has continued through multiple wet-dry climate cycles and is likely caused by increasing human impacts within the Okanagan region and possibly also climate change.

Total phosphorus (TP) had a year-over-year increasing trend at all sites from 2011-2022, and forms part of a longer-term trend since the mid-2000s. TP includes phosphorus associated with suspended sediment carried into the lake. It increased in Okanagan Lake during wet years such as 2017-2018 and decreased during dry years such as 2019 and 2021. Dissolved phosphorus is less affected by freshets than TP and was stable or declining at the three main basin sites while it also increased in the Armstrong Arm.

The ratio of total nitrogen to total phosphorus (N:P) available to phytoplankton will play a major role in which types of phytoplankton proliferate in a lake. A lower N:P ratio (abundant phosphorus relative to nitrogen) will favour the growth of cyanobacteria. The N:P ratio failed to meet the objective in the Armstrong Arm in 2022 with a downwards trend at all sites (farther from meeting objective).

## Biological Properties

Chlorophyll-a was used as a measure of photosynthetic activity in Okanagan Lake. A decreasing north to south trend in the chlorophyll-a data occurred over the course of this study. All sites met the chlorophyll-a objectives during 2022. However, a significant increasing trend occurred at Kelowna, Okanagan Centre, and Armstrong Arm from 2011-2022, part of a trend since the mid-2000s.

Phytoplankton abundance during 2022 was high compared to 2011-2021 because of elevated cyanobacteria densities. All sites met the phytoplankton biovolume objective but failed to meet the phytoplankton taxonomy objective during 2022 because of elevated cyanobacteria densities, particularly the Armstrong Arm.

Zooplankton biomass met the objective at Okanagan Centre in 2022. All sites failed to meet the objective of >5% cladocerans in some samples during 2022. A decline in cladoceran abundance was noted at Armstrong Arm from 2018-2022.

## Treated Water Quality Monitoring

Similar to the source water sampling program, over 2,750 combined treated water samples were tested from each of the four intake location immediately post UV and Chlorine treatment. The purpose of this monitoring program is to establish that the treatment is effectively removing or neutralizing any microbiological threat, improving, or at least not deteriorating the chemical and physical quality of the drinking water, and complying with the established GCDWQ health and aesthetic guidelines.



Detailed chemical and biological parameter descriptions, graphical trends, and related water quality objectives are listed in [Appendix C](#) and include:

- [Turbidity](#) (Table 18, Figures 23-24)
- [Free Chlorine](#) (Table 19, Figures 25-26)
- [Total Coliform](#) (Table 20)
- [Escherichia coli](#) (E. Coli.) (Table 21)
- [pH](#) (Table 22, Figures 27-28)
- [Color](#) (Table 23, Figures 29-30)
- [Temperature](#) (Table 24, Figures 31-32)
- [UV Transmittance](#) (Table 25, Figures 33-34)

## 2022 Treated Water Quality Observations

- Turbidity briefly exceeded 1 NTU at Poplar Point and Swick intakes during the month of June
- Treatment remained effective through complete deactivation of Total Coliform and E. coli. bacteria
- pH, color, chlorine residual, temperature, and UVT results were acceptable and remained consistent with previous year

## Annual Physical, Chemical and Biological Analysis

In addition to the on-site and in-lab analytical testing program, the COK submits treated water samples to an external accredited laboratory for full comprehensive physical, chemical, and microbiological analysis from each of the Intake sites. The purpose of utilizing an external lab is to verify internal test results as a quality control check and evaluate a broader range of compounds and highlight any water quality health concerns.

The 2021 analytical results validated the data generated by internal lab testing and did not indicate any significant year over year trend. There were no exceedances of aesthetic or health maximum guideline of any parameters listed and no significant trends relative to previous years of historical comprehensive analysis ([Table 26](#)).

## Pesticides and Herbicides

The Okanagan valley is renowned for its long standing agricultural industry and continues to be a hallmark of the BC interior region. Farming practices have commonly included the application of a variety of pesticides and



herbicides over the past 80 years. Although much of the hazardous compounds have been phased or legislated out, there are still some legacy chemical compounds that are monitored due to its lifespan in the environment. Due to the proximity of the agricultural land to Okanagan Lake, Herbicides and Pesticides are tested on a four-year cycle. Since the beginning of the quadrennial screening practice in 2000, none of the scanned Pesticides or Herbicides has been detected in any of the samples to date ([Table 27](#)). Testing was completed in 2021 and is next scheduled for 2025.

## Radiological

Radionuclides are naturally present in the environment and have been surveyed in various regions throughout British Columbia of which Uranium is the most common isotope identified in the Okanagan. Leaching of these radionuclides into ground water is of concern and therefore are measured against health standards. Maximum acceptable concentrations in drinking water have been established for three natural isotopes (<sup>210</sup>Pb, <sup>226</sup>Ra, and <sup>236</sup>U) and four artificial isotopes (<sup>90</sup>Sr, <sup>131</sup>I, <sup>137</sup>Cs, and H<sub>3</sub>-Tritium). To date, there has not been any significant Gross Alpha or Gross Beta radionuclides found in the drinking water ([Table 28](#)). Testing was last completed in 2022 and is scheduled again in 2026.

## Distribution System Testing Program

To maintain potable water service, bacteria, chlorine residual, and chlorination byproducts are routinely monitored and reported to Interior Health for compliance to *BC Drinking Water Regulations* and *Guidelines for Canadian Drinking Water Quality*. Representative distribution sampling sites and testing frequencies are determined by COK and approved by IHA on an annual basis. The sampling plan includes taking samples at the beginning, midpoint, and at the end of the main distribution pipes to ensure free chlorine residual is maintained and chlorination byproducts can be tested. Specific parameters that are monitored are listed in [Appendix D](#) and include:



- [Free Chlorine](#) (Table 29, Figures 36-37)
- [Total Coliform](#) (Table 30)
- [Escherichia coli](#) (E. Coli) (Table 31)
- [Trihalomethanes](#) (THM) (Table 32, Figures 38-39)
- [Haloacetic Acids](#) (HAA) (Table 33, Figures 40-41)

As per established GCDWQ guidelines, the following microbiological criteria for drinking water distribution systems are referenced:

- No sample should contain more than one *Escherichia Coli* organisms per 100mL
- No two consecutive samples from the same site should show the positive presence of Total Coliform organisms per 100mL
- At least 90% of the samples must have zero Total Coliform per 100mL

COK demonstrated that the treated drinking water met the guideline criteria for both Total Coliform and E. Coli. throughout 2021 with no recorded exceedances (Table 8).

| Criteria – Total Coliform                                  | City System | Swick System |
|--|-------------|--------------|
| Number of microbiological tests - Total Coliform           | 1400        | 180          |
| Number of samples containing positive Total Coliform/100mL | 0           | 0            |
| Samples with >10 Total Coliform / 100mL                    | 0           | 0            |
| Occasions with consecutive positive Total Coliform / 100mL | 0           | 0            |
| Criteria – Escherichia coli                                |             |              |
| Number of microbiological tests - E. Coli.                 | 1400        | 180          |
| Number of samples containing positive E. Coli. /100mL      | 0           | 0            |

**Table 8:** Summary of drinking water Bacterial tests

## 2022 Distribution Water Quality Observations

- Total Coliform and E. coli. counts all met drinking water quality objectives with no positive counts
- Chlorine disinfection was maintained but challenging in remote areas of the system
- Annual running average THM and HAA concentrations were below the drinking water guidelines

## Filtration Deferral Requirements

The City of Kelowna applied for filtration treatment exclusion in 2010 and was approved in 2011 based on the proviso that several treatment and water quality objectives be adopted, monitored, and reported to Interior Health on an annual basis. Since obtaining filtration exclusion, COK has continually met or exceeded the six requirements outlined by Interior Health and approved by the provincial Medical Health Officer.




## Dual Disinfection

In accordance with the IHA dual barrier approach for drinking water, all of the Okanagan Lake intake systems are equipped and utilize both Ultra Violet (UV) and chlorine disinfection prior to the water entering the distribution system. UV disinfection is currently applied at a minimal dose of 40 MJ/cm through the reactor cells and chlorine (Hypochlorite) dosed to maintain a minimum free chlorine residual of 0.2 mg/L in the distribution system. The O'Reilly well system is treated with Chlorine to a level of 0.5 mg/L and blended at Dall reservoir.

## Protozoa Sampling

Protozoa was analyzed extensively between 1996 and 2013 on raw and treated water samples throughout the COK water system. After consultation and review of the data with IHA, this requirement was removed from the scope in 2014 as it was demonstrated that the UV treatment adequately accounted for the deactivation and neutralization of all protozoa entering the water system.



## Source Water Protection

The COK relies on Federal and Provincial Acts, Regulations, Stewardship Plans, Best Management Practices and Local Government bylaws and policies to protect water resources from the impacts of land use in the watershed. As a condition on Permit to Operate, COK contracted an external Environmental consultant with the purpose of conducting and documenting a Source Water Protection Plan (SWPP) assessment. This was formally completed in 2011 with the intent that the resulting recommendations would trigger an assessment action response plan that would be annually reviewed and updated in accordance with the risks identified. Six main risk categories were identified as influential to the water quality for the COK and include:

- 1) Creek Flow
- 2) In-Lake Algal Production
- 3) Wastewater Treatment Plant Discharge
- 4) Transportation Corridor Spills
- 5) Boating Activities
- 6) Impact of Lake Physics

A formal source water protection plan was developed that addresses these risks through planning, mitigation, education, testing, and reporting.

- Drinking Water Intakes
  - During freshet, intake depth monitoring was completed by a consultant for the City to provide important data for our drinking water source by assessing creek plume movements and the potential impacts on intake turbidity.
- Upgrades to protect against invasive mussels
  - COK partners with the Okanagan Basin Water Boards (OBWB) "Don't Move a Mussel" program
- Stormwater management
  - Utility has developed an OGS program with the intent to install a new oil and grease (O&G) separator every 2 years over the next 10 years in high impact areas.
  - The Redlich Pond Study has been occurring for two consecutive years to monitor for nutrients, algae, and other water quality parameters to determine optimal practices to improve the water quality. In the fall of 2022 a pilot project was initiated where Bio-Islands were installed. Another set of bio-islands are scheduled to be installed in the spring of 2023 and post monitoring will occur to determine the water treatment effectiveness of the bio-islands.

- At Millard Pond a study was performed in the same format as the original Wetland Study (2019) to further assess the water quality at this location. Millard Pond is significant due to the pond being located downstream of a significant agricultural area as well as in the upper watershed of Brandt's Creek.
- Two studies for Sutherland Bay were initiated. The first study is to determine if Sutherland Bay is suitable to be used as a recreational beach site following the decommissioning of the former adjacent mill site. The second study is to determine the potential impacts to drinking and recreational water quality if a development was located in the former mill site water lot area.
- A snow storage study was completed in 2022 to determine snow storage impacts on surrounding surface water and ground sediments. A risk assessment was created to guide decisions on where snow should be stored to avoid environmentally sensitive areas.
- Public involvement
  - The city has two 'Clean water volunteer programs' that have been on a 2 year hiatus due to COVID-19 safety measures, and now have been re-initiated as of Spring 2022.
- Utility long range planning
  - Currently a Water Security Plan is being developed to better manage our water resource as a whole. This plan has been presented to council and is an ongoing process.
- Climate change
  - 10-year plan to restore and improve upstream water storage and mitigate flooding risk.
  - Okanagan flood story web-based resource made available, providing Okanagan Lake and river floodplain maps as well as good information for the public on how to prepare for the freshet season and potential flooding.

## Drainage Water Quality Program

As part of the COK *Source Water Protection Assessment Plan*, there are number of chemical and biological parameters that are tested and monitored at storm water outfalls and local tributaries that enter Okanagan Lake. Contaminants carried through the drainage system have the potential to impact the water quality at the intakes and therefore have been categorically assessed, recommendations made, and actions taken to mitigate and monitor the risks. Yearly assessments include correlating elevated Turbidity and E. Coli. levels in tributaries to the same parameters at intakes, recording water quality changes during rain and flushing events through the storm water system, summer beach sampling for E. Coli., and testing of routine water quality parameters in creeks at a minimum of 5 times a month to determine the level of nutrient and pathogen contribution to the lake water quality. Details of each category are listed with commentary in [Appendix E](#)




## Raw Water Bacteria

As per the annual COK water quality sampling program, source (raw) water was monitored for Total and E. Coli. Bacteria throughout the year at each intake. Results were collected and reviewed through the WaterTrax software system that allows for alert levels to flag and notify utility operators of elevated levels.

Corresponding monthly summary reports were issued to Interior Health as part of the Condition on Permit to operate and to assess if the water treatment is sufficiently neutralizing the raw water bacterial counts at the intake. For the 2022 calendar year, all samples from poplar Point, Cedar Creek, Eldorado, or Swick Road intakes met the Filtration Deferral criteria of having no more than 10% of the source water E. Coli. samples exceed 20/100ml in any 6-month period (Table 15 in [Appendix B](#))

## Raw Water Physical Parameters

In 2006, Interior Health introduced the Turbidity Education and Notification Campaign for unfiltered water systems to inform customers that health risks increase as Turbidity rises and to consider advisories (particularly for at-risk populations with weakened immune systems) for levels higher than one (1) Nephelometric Turbidity Units (NTU). None of the four COK intakes currently are equipped with filtration and therefore routine testing and reporting of Turbidity levels to Interior Health are required to demonstrate compliance.



Turbidity is continuously measured at all water supply sources via on-line Turbidity meters through SCADA and is primarily used as a screening or trending indicator for water quality. Samples are independently tested by City lab staff at regular intervals and with increased frequency if on-line monitors indicate that turbidity is approaching or exceeding the 1 NTU threshold. It is the lab tested data that is officially reported to the Interior Health.

Due to a late, prolonged freshet, elevated turbidity was noted at all intakes between June and July (Figures 3-5). Diligent monitoring, quality analysis, UV treatment adjustments, and communications with Interior Health precluded the Utility from having to issue a water quality advisory despite momentary excursions above 1 NTU.

In order to better understand the relationship and impact of these tributaries, the COK has implemented a weekly Lake depth sampling program during freshet that measures Turbidity at various depths in and around the main water intakes. The monitoring provides valuable and timely insight as to Turbidity plume direction and concentrations in the Lake as a result of run-off. Summary and commentary on these relationships can be found in the drainage report ([Appendix E](#)).

In addition to regular intake sampling, weekly depth sampling was conducted during freshet to capture high Turbidity plumes that may be emanating from some of the major tributaries. This provided insight as to conditions in and around the intake and allows for operation decisions and adjustments to be made as needed.






Figure 3. Turbidity values at Cedar Creek intake




Figure 4. Turbidity values at Poplar Point intake




Figure 5. Turbidity values at Swick intake

# Water Production

Water production within the COK service area is monitored at each pump station prior to treatment. The Poplar Point system accounts for 65% of the total annual domestic water production with the remaining 35% between Cedar Creek, Eldorado and Swick (Figure 6).




Figure 6. Monthly and total water production at each COK pump station

Production demand typically picks up in early May, peaks in late July / early August due to agriculture and irrigation demand and drops through October. 2022 was somewhat milder and wetter spring relative to 2019-2021, resulting in lower water demand on average. Water production peaked in early August at 90,616 m³ that coincided with elevated summer temperatures.




Figure 7. Peak daily water production volume trending

Similarly, the total water production has been tracked relative to the Utility area population over the past 16 years (Figure 8). Water volume production trend had remained relatively consistent up until 2020-2021 that had Southeast Kelowna demand added to the system as well as unprecedented heat and dry summer conditions.




Figure 8. Total water production relative to Utility population growth

Consumption is also tracked by service type and metered accounts and provides a correlation between what is produced and what is consumed. Discrepancies between the two values indicate potential water loss due to leakage or line flushing or as a result of unmetered accounts.

The number of metered service connections increased for most categories as has water demand in line with population growth. 2022 saw one an average precipitation rates over the summer and relatively moderate water demand. Water consumption per person in the Okanagan remains one of the highest in any region throughout Canada.

|   | 2016      | 2017      | 2018      | 2019      | 2020      | 2021      | 2022      | Unit                  |
|---|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------------------|
| <b>Production</b>                                   |           |           |           |           |           |           |           |                       |
| Total Pumped  | 15,512.80 | 15,833.28 | 15,712.41 | 15,650.00 | 16,503.87 | 17,346.75 | 15,589.19 | 1000 m <sup>3</sup>   |
| <b>Population within COK Water Utility Boundary</b> |           |           |           |           |           |           |           |                       |
| COK Water Utility Boundary                          | 70,694    | 73,542    | 74,679    | 75,370    | 83,529    | 85,238    | 86,663    | people                |
| <b>Climate</b>                                      |           |           |           |           |           |           |           |                       |
| Precipitation (April-September)                     | 148       | 99        | 134       | 146       | 183       | 73        | 136.9     | mm                    |
| <b>Number of Services (active and inactive)</b>     |           |           |           |           |           |           |           |                       |
| Residential   | 14,365    | 14,313    | 14,480    | 14,565    | 15,477    | 15,609    | 15,596    | services              |
| Multifamily   | 351       | 356       | 416       | 434       | 465       | 508       | 529       | services              |
| Strata  | 657       | 661       | 663       | 665       | 1165      | 1163      | 1177      | services              |
| Commercial  | 1,367     | 966       | 954       | 966       | 1,371     | 1,367     | 1,317     | services              |
| Parks   | 167       | 152       | 176       | 175       | 175       | 195       | 195       | services              |
| <b>Total</b>  | 16,907    | 16,448    | 16,689    | 16,805    | 18,653    | 18,842    | 18,814    | services              |
| <b>Consumption (Metered)</b>                        |           |           |           |           |           |           |           |                       |
| Residential   | 5,647.60  | 5,981.80  | 5,733.70  | 5,486.10  | 5,633.06  | 6,779.92  | 6,026.64  | 1000 m <sup>3</sup>   |
| Multifamily   | 2,443.00  | 2,502.20  | 2,703.30  | 2,804.65  | 2,917.17  | 3,161.28  | 3,036.19  | 1000 m <sup>3</sup>   |
| Strata  | 717       | 736.2     | 768.3     | 658.82    | 679.32    | 941.03    | 861.31    | 1000 m <sup>3</sup>   |
| Commercial  | 3,867.80  | 3,903.20  | 3,754.20  | 3,717.21  | 3,476.98  | 3,794.90  | 3,654.70  | 1000 m <sup>3</sup>   |
| Parks   | 498       | 499.8     | 578       | 564.7     | 517.56    | 676.6     | 676.62    | 1000 m <sup>3</sup>   |
| <b>Total</b>  | 13,173.40 | 13,699.00 | 13,537.50 | 13,231.48 | 13,224.08 | 15,353.78 | 14,255.46 | 1000 m <sup>3</sup>   |
| <b>Indicator</b>                                    |           |           |           |           |           |           |           |                       |
| Other Use*  | 2,201.10  | 2,134.28  | 2,174.91  | 2,418.52  | 3,279.79  | 1,992.97  | 1,333.73  | 1000 m <sup>3</sup>   |
| Max Day Demand                                      | 77.8      | 89        | 88.2      | 89.2      | 99.5      | 107.5     | 90.6      | 1000 m <sup>3</sup>   |
| Average Day Demand                                  | 42.4      | 43.4      | 43        | 42.9      | 45.2      | 47.5      | 42.7      | 1000 m <sup>3</sup>   |
| Utility wide Peak Day Demand                        | 989       | 1210      | 1182      | 1183      | 1067      | 1259      | 1046      | L/capita/day          |
| Utility wide Average Day Demand                     | 539       | 590       | 576       | 569       | 541       | 558       | 493       | L/capita/day          |
| Single Family Dwelling Demand                       | 403       | 418       | 402       | 382       | 369       | 441       | 392       | L/capita/day          |
| Average Monthly Residential Consumption per Service | 33        | 35        | 33        | 31        | 30        | 36        | 32        | m <sup>3</sup> /month |
| Peaking Factor (April-September)                    | 1.4       | 1.51      | 1.49      | 1.52      | 1.59      | 1.60      | 0.00      | L/capita/day          |
| Peaking Factor (October-March)                      | 1.7       | 1.8       | 1.44      | 1.4       | 1.93      | 1.49      | 1.90      | m <sup>3</sup> /month |

\*Includes water sold through filling stations, hydrant carts, utility use, fire department, and apparent losses

**Table 9. Summary of potable water production and consumption trends**

# Water Sustainability Management

The COK demand management programs are focused on reducing water demand both internally (such as the Parks department) and the customer point of use in order to achieve sustainable supply. High level water demand management strategies have been implemented including the mandatory installment of water meters for residential, commercial, and agriculture customers, tiered consumption-based water rates, and water conservation education programs. As climate change continues to accelerate, the message and mindset of water sustainability will need to take a high priority. The Utility has undertaken a number of initiatives that all contribute towards the efficient use of our shared water resource.



## Water Conservation

### Landscape Water Conservation Reports (LWCR)

Submission of Landscape Water Conservation Report is a bylaw requirement within Utility boundary for any irrigation installation or retrofit that covers an area greater than 100m<sup>2</sup> in order to confirm that acceptable watering systems and landscape materials are utilized. While the LWC report is a bylaw requirement by the homeowner, the majority of the reports are submitted by private contractors. Participation rates have historically been quite low (18%) due to enforcement challenges. Water Smart walk through follow up visits occurred at more than 20% of the sites in order to verify the water use efficiency and workmanship in relation to the submitted reports. The attributed water savings from this initiative were estimated at over 84,000,000 liters in 2022.

## Water Restrictions

Year round watering restrictions remain in place since first introduced in 2016. Allowable irrigation times for residential customers are limited to 3 days per week and specific times during the allowable day to minimize evaporation waste and maximize plant material uptake. Restrictions are intended to make residents cognoscente of their water usage and to reduce the daily water production peak demand. As with previous years, neighborhoods were patrolled for violations to the restrictions with notifications provided on compliance where needed. Water restrictions were set to Stage 1 in early July and has become an annual declaration for several years based on Okanagan Lake levels and demands put on the distribution system.



## Water Rebates

In order to assist residents to reduce water consumption, two rebates were offered in 2022: \$40 towards qualifying irrigation controller purchases and a matching rebate towards retrofitting residential and commercial landscapes and irrigation systems to more water efficient options. Estimated water savings for both rebates totaled over 2,000,000 liters in 2022 and will be carried over into 2023 for promotion.



## Eye-On-Water (EOW)

Residents receiving a new or retro-fitted water meter are given the opportunity to have their meter paired with new cellular meter reading technology that safely and securely collects and transmits water use data daily to the Utility. The added benefit of these devices is that property owners are given access to this information through a free downloadable application to track and manage their own water use as well as the option to be notified in the event that water is used on a continual basis for more than 24 hours. This allows the owner to investigate to determine if there is a potential leak and make necessary repairs before significant water damage and avoid substantial water bills.



## QWEL

The importance of proper planning, design and workmanship of irrigation systems and landscape selection is paramount to an effective water conservation program. Irrigation professionals significantly contribute to each of those stages and as such is vital that they apply water smart principles when designing and installing water systems and landscape materials. In order to accomplish this, the City of Kelowna became the first Canadian Professional Certifying Organization (PCO) to sponsor and endorse a Qualified Water Efficient Landscaper (QWEL) certification program. This training, testing, and on-site follow up inspection program provides an elevated level of contractor accountability. This ensures that knowledge and workmanship of these contractors are in line with water conservation in mind and suitable to our local climate. The city will promote this program and use this in the future as the benchmark for irrigation qualifications in the city along with the various Irrigation Industry Association of BC (IIABC) CIT, CIT2, and CID designations.



## Irrigation Assessments

The COK offers a number of services to assist residents with inspection, operation, and scheduling of their irrigation systems. Over 40 assessments were completed in 2022 for an estimated water savings of over 3,000,000 liters. Since inception in 2018, water saving of over 31,000,000 liters have been realized and has had excellent resident feedback. For more information on this program, please visit [www.kelowna.ca/watersmart](http://www.kelowna.ca/watersmart)

## Educational Outreach

Watersmart program participated in a number of community outreach events including social media campaigns (be a water hero), door hanger notifications, home show attendance, community group gatherings, gardening events, Park n Play booths and collaborative work with the Okanagan Basin Water Boards "Make Water Work" program that messages water conservation valley wide.

## Water Disruption Events

As with all water utilities, there are certain events throughout the year that interrupt water services – either planned or unplanned. These include pipe breaks, seized valves, leaking hydrants, and power outages. Regardless of cause, the COK strives to quickly correct the deficiencies with minimal disruption to water service as per AWWA standard C651-14. Summary of 2021 infrastructure replacement and repairs are captured in Table 10 relative to previous years.

|                                  | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 |
|----------------------------------|------|------|------|------|------|------|
| Water Main break repairs         | 8    | 7    | 17   | 9    | 20   | 11   |
| Water service leak repairs       | 121  | 103  | 123  | 116  | 80   | 88   |
| Fire Hydrant replacements        | 3    | 4    | 5    | 2    | 4    | 6    |
| Water Main Blow off replacements | 3    | 5    | 4    | 12   | 4    | 5    |
| Water Disruption Events          | 104  | 46   | 77   | 52   | 68   | 62   |

**Table 10.** 2017-2022 Infrastructure repairs, replacement, and disruption events

## Emergency Response and Notifications

The COK Water Utility and Communications department have developed a series of emergency protocol documents that are consulted in the event of water quality deviations or emergencies:

- Water Utility Emergency Preparedness and Response Plan
- Public Notification Protocol
- Turbidity Response Plan
- Drought Trigger Response Plan (OBWB developed plan)



These documents contain information on course of actions, list of appropriate contacts, and procedure necessary to assist operators and staff to make timely and informed decisions.

Residents and businesses are reminded to sign up on the City of Kelowna [e-subscribe](https://www.kelowna.ca) system, found on the city website at [www.kelowna.ca](https://www.kelowna.ca), that allows the selection and automatic notification delivery of a number of service updates, including water quality changes and advisories.

## Water Quality Notifications

Water Quality Advisories (WQA) and Boil Water Notices (BWN) are typically issued in conjunction with Interior Health for water systems that cannot meet the Canadian Water Quality Guidelines for either chemical and/or bacteriological parameters. The areas affected and length of the advisories are determined by the conditions and containment at the time of water main breaks, source water quality, effectiveness of disinfection, and subsequent water quality test results.

**Water Advisory in effect for this area.**

Consuming water from this source may pose a modest health risk.



[kelowna.ca](https://www.kelowna.ca)

Notifications are typically issued in the form of media releases, electronic sign boards, social media outlets, radio messages, automated email notifications for those registered on a sensitive customer list (hospitals, care homes, daycare, and schools). If a substantial number of customers are affected, additional notification includes website updates and links with specific instructions for food establishments, signage at public water fountains, washrooms, and facilities. Only one advisory was issued in 2022 for a period of 24 hours as a result of a main break in Hall road related to construction activity.

The Southeast Kelowna irrigation system, supplied by the Hydraulic Creek intake, is designated as permanently non-potable and under a permanent Boil Water Notice. All customers in Southeast Kelowna were notified of this status and advised to physically disconnect any on-property water connections between the potable drinking water pipes and non-potable irrigation system. Low winter irrigation demand resulted in the non-potable chlorination system being temporarily turned off in October through May.

## Service Requests and Responses

The COK provides residents a number of open and transparent options to report water and water quality related issues to the utility. These include a phone-in number as well as on-line service request form to submit electronically through the COK website. These are all documented and responded to in a timely fashion by related utility staff that are equipped to address the public concerns or comments.



There was a total of 128 service requests submitted and responded to by staff in 2022:

- Water Restrictions: 4
- Dirty/cloudy water: 11
- Taste and Odor: 19
- Drinking Water information: 13
- Pool discharge: 4
- Miscellaneous: 24
- Catch Basin discharge: 8
- Source water protection: 1
- Water Smart – Water Conservation: 44

This represents a 5% decrease in the number of requests primarily as a result of decreased water restrictions inquiries. However, a significant increase in water conservation requests were submitted.

## Long Term Improvements

The COK has a dedicated Utility Planning department that works in conjunction with Utility Operations in determining the design, implementation, and funding requirements for long term water service improvements. This requires reliable development forecasts, environmental considerations, government grant funding opportunities, and strategies that chart the path for future growth while balancing the sustainability of existing capital assets. The COK continues to charge an annual Water Quality Enhancement (WQE) fee to residents and businesses that is set aside to fund water quality capital improvement initiatives and future water filtration. A total of \$2.8M was contributed to the reserve fund for a total balance of \$13.5 million as of Dec 31, 2022.

Current and future initiatives include:

- Interconnections or Integration with surrounding water districts to improve water supply resiliency for all COK residents
- Upgrade of the Cedar Creek pump station and transmission main to increase capacity and decrease dependency on the seasonal Eldorado pump station
- Comprehensive Water Security Plan that incorporates a full overview and guidance on water quality, quantity and use in the Kelowna and surrounding area
- Utility / Water Quality Performance metrics for internal measurement and public reporting
- A Utility wide water meter replacement / cellular endpoint upgrade through 2026.

## Conclusion

The COK is committed to continually improving water quality and services to its residents, commercial users, and agriculture stakeholders. Protecting our water source is not an option – it is a requirement, for our current generation and those to come. To that end, the city has created a list of priorities of which providing safe and reliable drinking water is at the heart of leadership decisions. This requires extensive planning, funding, collaboration, vision, and leadership from City Council all the way through to the water utility staff and operators working diligently to support the Kelowna vision statement:



*"Kelowna, a City of the Future"*

City of Kelowna is pleased to present the 2021 Annual Water Quality Report, detailing the health and direction of our water system. If you have any questions about this report or wish to have additional information provided, please contact the COK Water Utility at 250-469-8502 or email [watersmart@kelowna.ca](mailto:watersmart@kelowna.ca)

## **Appendix A**

### 2022 Water Quality Sampling and Reporting Guidelines

### **Kelowna Water Utility - Water Quality Sampling Program 2022**

Kelowna Water Utility (KWU) currently operates four distinct water systems under two permits within the water Utility boundary. They consist of a primary City of Kelowna System and the Swick Road Water System.

1. **City of Kelowna System** – fed by Poplar Point intake and Cedar Creek intake supplemented by Eldorado intake when operationally required. The Poplar Point System is interconnected to the Cedar Creek System via a booster pump at Steele Road Reservoir as well as the Hubbard PRV. This system now supplies water to Southeast Kelowna domestic connections as of 2020 and is supplemented by O'Reilly Well when operationally required.
2. **Swick System** – small water system (~300 connections) fed by Swick Road intake off Okanagan Lake.

Water quality sampling is to be conducted in accordance with the BC Drinking Water Protection Regulation, 2005, Section 15 Schedule B, which states that the number of bacteriological samples taken per month is to be 1 per 1,000 of population. Based on 2021 Utility boundary population estimate of 87,787 residents, the City of Kelowna 2022 water quality sampling plan will meet and exceed the representative sampling requirements. Supplemental tests will be conducted in the event of water main breaks, re-tests, water advisories, or other irregular activities.

### **KWU 2022 Sampling Program**

#### **City of Kelowna and Swick Systems:**

##### **Daily On-line Data Monitoring**

- Source Water
  - pH, Turbidity, UVT, Conductivity, Temperature
- Treated Water
  - Free Chlorine, pH and Turbidity

##### **Weekly**

- Source Water
  - Total Coliform and E. Coli., Turbidity, Color, Temperature, UVT, pH
- Treated Water (Distribution)
  - Total Coliform and E. Coli., Turbidity, Color, Temperature, UVT, Total/Free Chlorine, Odor

##### **Quarterly (Treated Water)**

- Trihalomethanes, Haloacetic Acids, Total Organic Carbon (TOC)
- Ammonia and Algae (Cyanobacteria)

##### **Annual (Treated Water)**

- Comprehensive Chemical scan

##### **Quadrennial (Source Water)**

- Pesticide and Herbicide scan, Radiological parameters

### **Reporting**

All Drinking Water Quality and Drainage Water Quality data will be reported to the Watertrax data base.

Summary reports of the Drinking Water quality will be reported to IHA monthly and is to include:

#### **Drinking Water Quality**

- Turbidity, Free & total Chlorine - max, min, mean, number of tests
- Total Coliform and E. Coli, number of sites. Only positives will be location specific
- UVT on-line and grab samples tested in lab – max, min, mean, number of tests



- Operational activities, distribution events, and customer complaints
- Water production data, volume off spec water distributed, and any relevant events and activities
- THM and HAA quarterly

**\*Note**-During the winter months (November – March) there is a decrease in the number of sites sampled due to some sample stations not being compatible with the colder weather and freezing. Sampling frequency may also change relative to distribution events, construction, or necessary water advisories.

Water Quality Analyst will inform Water operators if elevated bacterial counts or turbidity are noted during source water quality monitoring for operational adjustments.

#### **Protocol for notification of positive E Coli. result in distribution system**

- KWU lab staff will provide immediate notification of positive E. Coli results to Chief Water Operator (CWO)
- CWO or designate will immediately contact IH Environmental Health Officer or designate and provide written copy of test results within 24 hours
- All positive E. Coli will be immediately resampled for confirmation
- Appropriate corrective actions will be determined in collaboration with IHA

#### **Protocol for notification of positive Total Coliform result in distribution system**

- All positive Total Coliform results will be reported to CWO and will be resampled immediately
- If the following criteria is met, KWU will immediately contact the IH Environmental Health Officer:
  1. Result is greater than 10 MPN or CFU per 100mL or if more than one sample is TC positive in a sampling period.
  2. Consecutive resample results are positive
  3. Positive result is under anomalous or suspicious conditions
- Appropriate corrective actions will be determined in collaboration with IHA

#### **Protocol for reporting of abnormal sampling conditions or results in distribution system and raw water**

- If abnormal conditions are noted by the sampler (low chlorine residual for the area, sample station damage, flooding, conditions preventing sampling collection (frozen tap), or increased raw water bacteria) will be recorded on the field data record sheet. Related qualifiers will be put on the monthly report as required.

#### **Drainage Water Quality**

- **Regular Sampling**- The standard drainage water quality scan (SDWQS) includes ammonia, chloride, colour, conductivity, dissolved oxygen, *E. Coli*, pH, ortho-phosphate, nitrate, suspended solids, temperature, and turbidity and is analysed in-house. Site number may change due to seasonal variations.
- **5/30 (A- Creek Water)**- For filtration exclusion, the mouths of Mission Creek, Mill Creek, and Brandt's Creek are sampled 5 times in 30 days from April 15<sup>th</sup> to September 15<sup>th</sup>, analysed for the SDWQS, and included in the annual report. During freshet the mouths of Varty Creek, Lebanon Creek, Bellevue Creek, Mission Creek, Mill Creek, Brandt's Creek, and Bear Creek are sampled weekly.
- **Water Quality at Intakes (B- Creek Water)**- for filtration exclusion, the mouths of Mission Creek, Mill Creek, and Brandt's Creek are sampled when decreased water quality of raw water at the intakes occurs, analysed for the SDWQS and included in the annual report.
- **Storm Water**- For filtration exclusion, first flush and subsequent rain event samples are collected at selected outfalls on Mill Creek and Brandt's Creek, analysed for the SDWQS, and included in the annual report.
- **Storm / Sanitary interconnect**- For filtration exclusion, Fascieux Creek is sampled approx.3 times per year at 3 locations during rain events, analysed for the SDWQS, and included in the annual report.
- **Irregular events**- Samples may be analysed for parameters in the SDWQS suite (samples may be sent to a private lab for further analysis if the situation dictates). Discretion of either the Water Quality Technician or IHA Environmental Health Officer relative to circumstance.

**Beach Water Quality**

- **Regular testing-** Samples from the 6 most populated beaches within the Kelowna Utility are sampled and tested weekly for Total Coliform and E. coli. counts between May and September. Samples are submitted to an independent accredited laboratory of Interior Health's choosing with results directly reported to Interior Health and posted on their related webpage.
- **Irregular events-** In the event of a positive bacterial count over recreational water quality guidelines or an indication of increasing risk based on trending bacterial counts, in consultation with IHA, the EWQA accredited City laboratory can independently re-sample and test beach sites and report to Interior Health for consideration and expedite decisions as to potential beach water quality notifications. Parameters such as Algae or other biological or chemical compounds would be sampled as needed and sublet to an external laboratory for analysis.

## **Appendix B**

### Source Water Quality Monitoring Parameters

## Source Water Quality Parameters

### Turbidity

Turbidity measurements are related to the optical properties of water. Suspended materials such as clay, silt, organic and inorganic particles, plankton, and other microscopic organisms all contribute to Turbidity and can have a negative effect on disinfection techniques.

Monthly average turbidity remained under 1.0 NTU despite some short lived, elevated events during June through July that peaked above 1 NTU. The YOY average and maximum values increased as did the number of exceedances over 1 NTU (Table 11). The 5-year Turbidity trend at Poplar Point indicates a marginal decrease after high flows experienced in 2017 and 2018 (Figures 10).

| Intake       | Average (NTU) | Minimum (NTU) | Maximum (NTU) | Guideline (NTU) | Number of Exceedances | Number of Tests in 2022 |
|--------------|---------------|---------------|---------------|-----------------|-----------------------|-------------------------|
| Poplar Point | 0.379         | 0.168         | 1.65          | <1.0            | 7                     | 176                     |
| Eldorado     | 1.000         | 0.721         | 1.47          | <1.0            | 2                     | 7                       |
| Cedar Creek  | 0.424         | 0.243         | 0.816         | <1.0            | 0                     | 43                      |
| Swick        | 0.400         | 0.152         | 1.44          | <1.0            | 3                     | 94                      |

Table 11. Source Water Turbidity annual summary





Figure 9. Monthly Turbidity average at Intake source



**Figure 10.** 5-Year Turbidity trend in Source Water

## Total Coliform

The coliform group consists of several genera of bacteria belonging to the Enterobacteriaceae family. The detection of these bacteria can be determined with a variety of analytical techniques including membrane filtration and lactose fermentation. The COK utilizes the Quanti-tray method which is based on the fermentation technique which involves a reaction with an enzymatic substrate. The water sample reacts with the enzymes in multiple wells or tubes over 18-24 hours and generates a detectable yellow color for positive Total Coliform. The replicate wells are reported in terms of the Most Probable Number (MPN) which is statistically derived number to determine the presence of the coliform.

The average coliform concentrations in 2022 was consistent with previous years counts as well as the last 3 years for all intake sites (Figures 11-12).

| Intake       | Average (MPN/100ml) | Minimum (MPN/100ml) | Maximum (MPN/100ml) | Number of Tests in 2022 | # of Tests >100 MPN | 2021 % of Tests >100MPN | 2022 % of Tests >100MPN |
|--------------|---------------------|---------------------|---------------------|-------------------------|---------------------|-------------------------|-------------------------|
| Poplar Point | 2                   | 0                   | 13.2                | 172                     | 0                   | 0                       | 0                       |
| Eldorado     | 4                   | 0                   | 13.4                | 6                       | 0                   | 0                       | 0                       |
| Cedar Creek  | 1                   | 0                   | 9.8                 | 43                      | 0                   | 0                       | 0                       |
| Swick        | 2                   | 0                   | 16.1                | 93                      | 0                   | 0                       | 0                       |

**Table 12.** Source Water Total Coliform annual summary




Figure 11. Monthly Total Coliform average at Intake source




Figure 12. 5-Year Total Coliform trend in Source Water



## E. Coli.

*Escherichia coli* (E. Coli.) is a sub-category within the coliform family and is used as a high risk indicator of harmful pathogens derived from human or animal fecal matter. The principle behind the methodology to detect E. Coli. is identical to the Total Coliform method in that an enzymatic reaction and subsequent fermentation is used to produce a detectable presence of the pathogen. The unique characteristic of E. Coli. using this technique is that in the presence of a long wave UV lamp (365nm), the resulting sample wells fluoresce. The number of wells that fluoresce are counted and calculated and reported as MPN values.

Similar to Total Coliform, the levels of E. Coli. remained relatively and consistently low relatively low in term of average and maximum number of counts compared to previous years. All results were within the filtration exclusion guideline of no more than 10% of E. coli. counts to exceed 20 MPN/100mL (Table 13, Figures 13-14).

| Intake       | Average (MPN/100ml) | Minimum (MPN/100ml) | Maximum (MPN/100ml) | Number of Tests in 2022 | # of Tests >20 MPN | % of Tests >20MPN |
|--------------|---------------------|---------------------|---------------------|-------------------------|--------------------|-------------------|
| Poplar Point | 1.0                 | 0                   | 4.1                 | 172                     | 0                  | 0                 |
| Eldorado     | 1.0                 | 0                   | 1                   | 6                       | 0                  | 0                 |
| Cedar Creek  | 1.0                 | 0                   | 1                   | 43                      | 0                  | 0                 |
| Swick        | 1.1                 | 0                   | 5.2                 | 93                      | 0                  | 0                 |

Table 13. Source Water E. Coli.





Figure 13. Monthly E. Coli. average at Intake source



**Figure 14.** 5-Year E. Coli. trend in Source Water

## pH

Measurement of pH is one of the most important and frequently used tests in water chemistry. Practically every aspect of water supply and treatment is pH dependent such as acid-base neutralization, water softening, precipitation, coagulation, disinfection, and corrosion control. At a given temperature, the intensity of the acidic or basic character of a solution is indicated by pH or hydrogen ion activity. Natural waters tend to have a pH value in the range of 4-9, and most are slightly basic (7.5-9) due to the presence of bicarbonates and carbonates of the alkali and alkaline earth metals in the environment.

The pH remained firmly alkaline for each of the intakes and within the objective range of 7.5-10 with no instances of exceedance (Table 14). The 5-year trend indicates a gradual increase in contrast to the lower pH experienced during the 2017-2018 flooding event years (Figure 17).

| Intake       | Average | Minimum | Maximum | Guideline  | Number of Exceedances | Number of Tests in 2022 |
|--------------|---------|---------|---------|------------|-----------------------|-------------------------|
| Poplar Point | 8.05    | 7.74    | 8.33    | 7.0 - 10.5 | 0                     | 167                     |
| Eldorado     | 8.10    | 7.97    | 8.27    | 7.0 - 10.5 | 0                     | 5                       |
| Cedar Creek  | 8.06    | 7.82    | 8.25    | 7.0 - 10.5 | 0                     | 43                      |
| Swick        | 8.01    | 7.75    | 8.29    | 7.0 - 10.5 | 0                     | 89                      |

**Table 14.** Source Water pH annual summary




Figure 15. Monthly pH average at Intake source




Figure 17. 5-Year pH trend in Source Water


## Color

Color in surface waters result primarily from the presence of natural organic humic matter. Humic matter consists of humic and fulvic acids; both of which cause a yellow-brown color that can be measured by spectrophotometer wavelength. Color is preferred to be kept to a minimum as those compounds are considered precursors in the formation of chlorine disinfection byproducts such as chloroform. Assessment of color data is primarily gauged against an aesthetic objective of 15 color units.


Color remained consistent with historical averages with a decrease in the number of samples exceeding the Aesthetic objective of 15 ACU during the summer months (Table 15, Figures 17-18).

| Intake       | Average (ACU) | Minimum (ACU) | Maximum (ACU) | Guideline (ACU) | Number of Exceedances | Number of Tests in 2022 |
|--------------|---------------|---------------|---------------|-----------------|-----------------------|-------------------------|
| Poplar Point | 8             | 3             | 25            | AO: ≤15         | 6                     | 174                     |
| Eldorado     | 17            | 12            | 22            | AO: ≤15         | 4                     | 7                       |
| Cedar Creek  | 11            | 6             | 27            | AO: ≤15         | 1                     | 43                      |
| Swick        | 9             | 2             | 22            | AO: <15         | 8                     | 94                      |

**Table 15.** Source Water Color annual summary



**Figure 17.** Monthly Apparent Color average at Intake source



**Figure 18.** 5-Year Apparent Color trend in Source Water

## Temperature

Temperature is an important factor to consider in water quality as it has influences on several other parameters and can alter the physical and chemical properties of water. Water temperature is considered when determining:

- Metabolic rates of aquatic life
- Dissolved Oxygen
- Conductivity and Salinity
- pH
- Water Density

Temperature fluctuations also plays an important role in the lake limnology which can transport nutrients and potential contaminants to the water intake sources. The COK operational objective is to consistently draw from water source at  $<15^{\circ}\text{C}$ , which was maintained 98% of the time at the intake sites (Table 16). 5-year trend indicates a marginal  $0.1\text{--}0.6^{\circ}\text{C}$  increase in temperature at the intakes (Figure 20).

| Intake       | Average (°C) | Minimum (°C) | Maximum (°C) | Guideline (°C) | Number of Exceedances | Number of Tests in 2022 |
|--------------|--------------|--------------|--------------|----------------|-----------------------|-------------------------|
| Poplar Point | 6.1          | 3.5          | 11           | AO: $\leq 15$  | 0                     | 176                     |
| Eldorado     | 14.2         | 10.0         | 18.5         | AO: $\leq 15$  | 2                     | 7                       |
| Cedar Creek  | 7.4          | 3.5          | 14.5         | AO: $\leq 15$  | 0                     | 43                      |
| Swick        | 9.6          | 4.0          | 19.5         | AO: $\leq 15$  | 9                     | 94                      |

**Table 16.** Source Water Temperature annual summary




Figure 19. Monthly Water Temperature average at Intake source




Figure 20. 5-Year Temperature trend in Source Water




## UV Transmittance

Ultra Violet transmittance (UVT) represents the amount of light transmitted through water and is used to gauge the effectiveness of the UV light will be on the disinfection of the drinking water. The higher the Transmittance, the less UV dosing, in theory, is required to treat the sample. It is important to note that both solid and dissolved compounds have the ability to absorb UV light, which in turn has a negative impact on UVT.

UVT is measured on unfiltered samples (representative of treatment type) at a wavelength of 254nm and reported as a percentage. All source water samples remained above the UVT operational >80% objective with a minimal number of samples measuring just below that threshold (Table 17, Figure 21). Lab equipment failure during November resulted in small data gap. No detectable trend was noted overall in the 5-year trend (Figure 22).

| Intake       | Average (%T) | Minimum (%T) | Maximum (%T) | Objective (%T) | Number of Deficiencies | Number of Tests in 2022 |
|--------------|--------------|--------------|--------------|----------------|------------------------|-------------------------|
| Poplar Point | 85.7         | 82.4         | 89.4         | >80            | 0                      | 152                     |
| Eldorado     | 83.3         | 82.0         | 86.4         | >80            | 0                      | 6                       |
| Cedar Creek  | 85.2         | 82.7         | 86.9         | >80            | 0                      | 73                      |
| Swick        | 85.4         | 81.7         | 88           | >80            | 0                      | 84                      |

**Table 17.** Source Water UV Transmittance annual summary



**Figure 21.** Monthly UVT average at Intake source





Figure 22. 5-Year UVT trend in Source Water

Algae

The number and types of algae present in Okanagan Lake provide excellent water quality for most of the year. In the surface water, peak algae growth follows the spring overturn, followed by a lull during late July and August as key nutrients and vitamins are exhausted, and finally a smaller peak in cyanobacteria (blue-green algae) near the fall overturn. Cyanobacteria counts in intake samples often include species that inhabit deep water or grow along the substrate. Cyanobacteria are a problematic group of organisms in which some types can generate toxins, and all types contain BMAA, and they readily form THM's (Trihalomethanes) after disinfection with chlorine. Okanagan Lake has been dominated by cyanobacteria for at least 70 years. Since 2006, the COK has contracted Larratt Aquatic Environmental consultants to conduct quarterly Microcystin sampling and analysis to determine concentrations of Cyanobacteria and general Algal biomass that would have an impact on water quality at the intake systems.



The last four years of algae monitoring have revealed increasing algae activity. Total algae concentrations between 2019 and 2022 represent the highest annual averages since 2014 at the three most-active intakes (Poplar, Swick and Cedar Creek). Annual algae densities decreased from record high values during 2021, but cyanobacteria concentrations remained elevated compared to previous years at all sites (Eldorado intake was not sampled during

2022). Recent elevated counts may be attributed to the large freshets and flooding events during 2017, 2018, 2020, and 2022. Increased algae concentrations in 2021 and 2022 may have also been affected by regional wildfire activity. Additional data is needed to understand the impact from the intense 2021 wildfire year.

Over the years, average algae densities were moderate with algae spikes resulting in deep and/or bottom-dwelling cyanobacteria counts exceeding 2000 cells/mL. Turbidity also spiked during some of these events, suggesting that seiches were involved. Poor correlations between algae counts and turbidity indicate that most turbidity was caused by fine silt particles, primarily from creek plumes.

Intake depth in Okanagan Lake is an important determinant of the types and density of algae that will be drawn into the distribution system. The deepest intake, Poplar Point, contained the lowest 2022 average algal count ( $1115 \pm 709.4$  cells/mL) while the shallowest had the highest ( $2238 \pm 1431$  cells/mL).




Figure 23. Cyanotoxin Risks in Intake Source Water

**Appendix C**

Treated Water Quality Monitoring Parameters


## Treated Water Quality Parameters

### Turbidity


The primary function of monitoring the Turbidity post treatment is to ensure that the chlorination and UV dosing has not detrimentally affected the water quality and meets operational objective targets. Relative to the source water Turbidity, the level of treated water concentrations and exceedances remained relatively consistent (Table 18). Short lived Turbidity events exceeded guidelines, but quickly dropped to below 1 NTU. Monthly average, apart from Eldorado in June, remained under 1 NTU. Overall Turbidity trend for 2022 indicated a general increase over the past 3 years, but lower than experienced in 2017-2018 flooding years (Figure 25).

| Intake       | Average (NTU) | Minimum (NTU) | Maximum (NTU) | Guideline (NTU) | Number of Exceedances | Number of Tests in 2022 |
|--------------|---------------|---------------|---------------|-----------------|-----------------------|-------------------------|
| Poplar Point | 0.391         | 0.148         | 1.86          | <1.0            | 6                     | 178                     |
| Eldorado     | 1.000         | 0.563         | 1.44          | <1.0            | 5                     | 13                      |
| Cedar Creek  | 0.386         | 0.197         | 0.987         | <1.0            | 0                     | 91                      |
| Swick        | 0.411         | 0.196         | 1.310         | <1.0            | 4                     | 94                      |

**Table 18.** Annual Treated Water Turbidity summary



**Figure 24.** Monthly average Turbidity of Treated Water



**Figure 25.** 5-Year Turbidity trend in Treated Water

## Chlorine – Free

Chlorine is introduced to source water at each pump house through exposure and mixing with either chlorine gas or commercial hypochlorite at set time levels and concentrations that meet the criteria of 3 and 4-log reduction of bacteria and pathogens. Both Total and Free Chlorine are measured to ensure that the initial chlorine demand does not exceed the dosing applied and is at appropriate levels to maintain a residual throughout the entire length of the distribution system. Free Chlorine is primarily monitored as that is the form of chlorine available to neutralize pathogens beyond the initial dosing point.

The average Free Chlorine value at each intake immediately post treatment met the operational objectives in 2022 (Table 19, Figure 26). Overall, there is a marginal increase in free chlorine over the past 5 years (Figure 27).

| Intake       | Average (mg/L) | Minimum (mg/L) | Maximum (mg/L) | Objective (mg/L) | Number of Tests in 2022 |
|--------------|----------------|----------------|----------------|------------------|-------------------------|
| Poplar Point | 1.63           | 0.91           | 2.20           | 0.20             | 177                     |
| Eldorado     | 1.59           | 0.87           | 1.81           | 0.20             | 12                      |
| Cedar Creek  | 1.52           | 0.74           | 2.02           | 0.20             | 90                      |
| Swick        | 0.98           | 0.25           | 1.92           | 0.20             | 94                      |

**Table 19.** Treated Water Free Chlorine annual summary




Figure 26. Monthly average Free Chlorine of Treated Water




Figure 27. 5-Year Free Chlorine trend in Treated Water



## Total Coliform

Effectiveness of water treatment is measured by the viable presence of both Total Coliform and E. Coli. bacteria. At no point throughout 2022 was there any positive Total Coliform detected immediately post treatment. This is in line with the 5-year trend and the CDWQ guideline requirement of <1 MPN/100mL. (Table 20). Important to note that the reporting requirement of the MPN Quanti-tray method produces a minimum value of <1 MPN/100mL, which is essentially equivalent to the CDWQ guideline of zero CFU/100mL.

| Intake       | Average (MPN/100ml) | Minimum (MPN/100ml) | Maximum (MPN/100ml) | Guideline (MPN/100ml) | Number of Exceedances | Number of Tests in 2022 |
|--------------|---------------------|---------------------|---------------------|-----------------------|-----------------------|-------------------------|
| Poplar Point | <1.0                | <1.0                | <1.0                | <1.0                  | 0                     | 174                     |
| Eldorado     | <1.0                | <1.0                | <1.0                | <1.0                  | 0                     | 9                       |
| Cedar Creek  | <1.0                | <1.0                | <1.0                | <1.0                  | 0                     | 90                      |
| Swick        | <1.0                | <1.0                | <1.0                | <1.0                  | 0                     | 93                      |

**Table 20.** Total Coliform in Treated Water annual summary

## E. Coli.

The guideline objective for E. Coli. are identical to that of Total Coliform in that all viable bacteria related to Fecal matter requires complete and full inactivation (<1 MPN/100mL). The objective was achieved at all treatment points throughout 2022 (Table 21) with no requirement for the issue of any Boil Water Notices (BWN).

| Intake       | Average (MPN/100ml) | Minimum (MPN/100ml) | Maximum (MPN/100ml) | Guideline (MPN/100ml) | Number of Exceedances | Number of Tests in 2022 |
|--------------|---------------------|---------------------|---------------------|-----------------------|-----------------------|-------------------------|
| Poplar Point | <1.0                | <1.0                | <1.0                | <1.0                  | 0                     | 173                     |
| Eldorado     | <1.0                | <1.0                | <1.0                | <1.0                  | 0                     | 9                       |
| Cedar Creek  | <1.0                | <1.0                | <1.0                | <1.0                  | 0                     | 90                      |
| Swick        | <1.0                | <1.0                | <1.0                | <1.0                  | 0                     | 93                      |

**Table 21.** E.coli. in Treated Water annual summary

## pH

The pH level of the water has a direct influence on the effectiveness and efficiency of the chlorine treatment applied as well as impact on the rate of infrastructure corrosion. Ideal range of pH for maximum chlorine disinfection (Hypochlorous acid) is between 6-7, but corrosion is a concern at levels <7.5. The pH of treated water is similar to the source water and is not significantly altered in any fashion. Levels were consistently within the target guideline range at all treatment points (Table 22). The 5-year trend indicates a rebound of recent pH values to a more alkaline condition in the lake (Figure 29).

| Intake       | Average | Minimum | Maximum | Guideline (AO) | Number of Exceedances | Number of Tests in 2022 |
|--------------|---------|---------|---------|----------------|-----------------------|-------------------------|
| Poplar Point | 7.96    | 7.69    | 8.18    | 7.0 - 10.5     | 0                     | 167                     |
| Eldorado     | 7.99    | 7.9     | 8.17    | 7.0 - 10.5     | 0                     | 7                       |
| Cedar Creek  | 8.08    | 7.88    | 8.26    | 7.0 - 10.5     | 0                     | 90                      |
| Swick        | 8.08    | 7.89    | 8.32    | 7.0 - 10.5     | 0                     | 90                      |

Table 22. Treated Water pH annual summary





Figure 28. Monthly average pH of Treated Water



**Figure 29.** 5-Year pH trend in Treated Water

## Color

Drinking water color below 15 Apparent Color Units (ACU) is typically undistinguishable to the average person. Elevated levels of color post treatment can have a direct connection to the concentration levels of chlorination byproducts such as THM's and HAA's. As with previous year data, chlorination and UVT treatment resulted in a 2-3 color unit drop in the treated water minor exceedance above the Aesthetic objective of 15 ACU during freshet (Table 23). There has been a <5% increase in the overall Color intensity at Poplar Point over the 5-year average (Figure 31).

| Intake       | Average (ACU) | Minimum (ACU) | Maximum (ACU) | Objective (ACU) | Number of Exceedances | Number of Tests in 2022 |
|--------------|---------------|---------------|---------------|-----------------|-----------------------|-------------------------|
| Poplar Point | 6             | 3             | 24            | AO: ≤15         | 2                     | 175                     |
| Eldorado     | 15            | 11            | 23            | AO: ≤15         | 5                     | 12                      |
| Cedar Creek  | 7             | 3             | 14            | AO: ≤15         | 0                     | 90                      |
| Swick        | 7             | 3             | 17            | AO: ≤15         | 5                     | 93                      |

**Table 23.** Treated Water Color annual summary




Figure 30. Monthly average Color for Treated Water





Figure 31. 5-Year Color trend in Treated Water

## Temperature


The water temperature levels post treatment is not significantly different that the source water temperature as there is little heating or chilling applied during the treatment process. Elevated temperatures in treated water have been proven to enhance THM byproduct formation and therefore are preferred to be within objective limits. Minor objective exceedances were observed for both source and treated water during summer season, particularly at the shallower intakes at Eldorado and Swick (Table 24). There is a marginal upward trend in the 5-year average temperature (Figure 33).

| Intake       | Average (°C) | Minimum (°C) | Maximum (°C) | Objective (°C) | Number of Exceedances | Number of Tests in 2022 |
|--------------|--------------|--------------|--------------|----------------|-----------------------|-------------------------|
| Poplar Point | 6.4          | 3.5          | 12.5         | AO:≤15         | 0                     | 176                     |
| Eldorado     | 14.7         | 11.0         | 21.0         | AO:≤15         | 4                     | 12                      |
| Cedar Creek  | 7.4          | 4.0          | 14.0         | AO:≤15         | 0                     | 93                      |
| Swick        | 10.7         | 4.0          | 19.5         | AO:≤15         | 9                     | 94                      |

**Table 24.** Treated Water Temperature annual summary



**Figure 32.** Monthly average Temperature of Treated Water



**Figure 33.** 5-Year Temperature trend in Treated Water

## UV Transmittance

After dosing through the UV reactor cells, the transmittance of the treated water is increased by an average of 2% over the UV transmittance of the source water for all sites. All test results met the objective of >80% transmittance throughout 2021 and similar to the raw water, there was a noticeable increase in water clarity all intakes after treatment (Table 25). There was a minor decreasing trend in UVT over the past 5 years (Figure 35).

| Intake       | Average (%T) | Minimum (%T) | Maximum (%T) | Objective (%T) | Number of Exceedances | Number of Tests in 2022 |
|--------------|--------------|--------------|--------------|----------------|-----------------------|-------------------------|
| Poplar Point | 88.5         | 84.1         | 90.3         | >80            | 0                     | 153                     |
| Eldorado     | 85.4         | 83.7         | 87.2         | >80            | 0                     | 11                      |
| Cedar Creek  | 88.4         | 86           | 90.3         | >80            | 0                     | 80                      |
| Swick        | 87.4         | 83.8         | 90.1         | >80            | 0                     | 84                      |

**Table 25.** Treated Water UV Transmittance annual summary




Figure 34. Monthly average % UVT for Treated Water




Figure 35. 5-Year %UVT trend in Treated Water



## Annual Physical, Chemical and Biological Analysis

Comprehensive water analysis is conducted annually at each intake and compared to a variety of health and aesthetic objectives. There were no guideline exceedances for any of the parameters as per CDWQ guidelines (Table 26).

| Caro Analytical Services                  |              |              | Poplar Point Treated | Eldorado Treated | Cedar Treated | Swick Treated |
|---|--------------|--------------|----------------------|------------------|---------------|---------------|
| Date Sampled                              |              |              | 28-Jul-2022          | 28-Jul-2022      | 28-Jul-2022   | 28-Jul-2022   |
| <b>Physical Tests (Water)</b>             | <b>Units</b> | <b>CDWQG</b> | Water                | Water            | Water         | Water         |
| Colour, True                              | CU           | AO≤15        | <5.0                 | <5.0             | <5.0          | <5.0          |
| Conductivity (EC)                         | uS/cm        |              | 280                  | 271              | 287           | 290           |
| Hardness, Total (as CaCO <sub>3</sub> )   | mg/L         |              | 126                  | 118              | 124           | 122           |
| pH  | pH units     | 7.0-10.5     | 8.04                 | 8.06             | 8.11          | 8.17          |
| Alkalinity, Total (as CaCO <sub>3</sub> ) | mg/L         |              | 122                  | 115              | 118           | 126           |
| Solids, Total Dissolved                   | mg/L         | AO≤500       | 169                  | 159              | 169           | 174           |
| Turbidity                                 | NTU          | MAC=1        | 0.34                 | 0.76             | 0.43          | 0.6           |
|   |              |              |                      |                  |               |               |
| <b>Anions and Nutrients (Water)</b>       | <b>Units</b> |              |                      |                  |               |               |
| Ammonia, Total (as N)                     | mg/L         |              | <0.050               | <0.050           | <0.050        | <0.050        |
| Chloride                                  | mg/L         | AO≤250       | 7.52                 | 7.13             | 8.71          | 9.79          |
| Fluoride                                  | mg/L         | MAC=1.5      | 0.13                 | 0.12             | 0.13          | 0.13          |
| Nitrate (as N)                            | mg/L         | MAC=10       | 0.063                | <0.010           | 0.023         | <0.010        |
| Nitrite (as N)                            | mg/L         | MAC=1        | <0.010               | <0.010           | <0.010        | <0.010        |
| Sulfate                                   | mg/L         | AO≤500       | 29.2                 | 27.6             | 28.5          | 28.2          |
| Carbon, Total Organic                     | mg/L         |              | 3.83                 | 4.23             | 4.15          | 3.97          |
| Cyanide, Total                            | mg/L         | MAC=0.2      | <0.0020              | <0.0020          | <0.0020       | <0.0020       |

| Caro Analytical Services    |              |           | Poplar Point Treated | Eldorado Treated | Cedar Treated | Swick Treated |
|-----------------------------|--------------|-----------|----------------------|------------------|---------------|---------------|
| Date Sampled                |              |           | 28-Jul-2022          | 28-Jul-2022      | 28-Jul-2022   | 28-Jul-2022   |
|                             |              |           |                      |                  |               |               |
| <b>Total Metals (Water)</b> | <b>Units</b> |           |                      |                  |               |               |
| Aluminum, total             | mg/L         | OG<0.1    | 0.0101               | 0.0277           | 0.0128        | 0.0104        |
| Antimony, total             | mg/L         | MAC=0.006 | <0.00020             | <0.00020         | <0.00020      | <0.00020      |
| Arsenic, total              | mg/L         | MAC=0.01  | 0.00054              | <0.00050         | 0.00051       | <0.00050      |
| Barium, total               | mg/L         | MAC=2     | 0.0218               | 0.0212           | 0.0211        | 0.0201        |
| Boron, total                | mg/L         | MAC=5     | <0.0500              | <0.050           | 0.0679        | <0.0500       |
| Cadmium, total              | mg/L         | MAC=0.005 | <0.000010            | <0.000010        | <0.000010     | <0.000010     |
| Calcium, total              | mg/L         |           | 34.2                 | 32.1             | 33.5          | 33.2          |
| Chromium, total             | mg/L         | MAC=0.05  | <0.00050             | <0.00050         | <0.00050      | <0.00050      |
| Cobalt, total               | mg/L         |           | <0.00010             | <0.00010         | <0.00010      | <0.00010      |
| Copper, total               | mg/L         | MAC=2     | 0.00111              | 0.0333           | 0.00105       | 0.00219       |
| Iron, total                 | mg/L         | AO<=0.3   | 0.012                | 0.036            | 0.011         | 0.01          |
| Lead, total                 | mg/L         | MAC=0.005 | <0.00020             | 0.00021          | <0.00020      | <0.00020      |
| Magnesium, total            | mg/L         |           | 9.87                 | 9.1              | 9.67          | 9.43          |
| Manganese, total            | mg/L         | MAC=0.12  | 0.00145              | 0.00164          | 0.00104       | 0.00111       |
| Mercury, total              | mg/L         | MAC=0.001 | <0.000010            | <0.000010        | <0.000010     | <0.000010     |
| Molybdenum, total           | mg/L         |           | 0.00337              | 0.00321          | 0.00334       | 0.00323       |
| Nickel, total               | mg/L         |           | 0.00047              | 0.00049          | 0.00052       | 0.00042       |
| Potassium, total            | mg/L         |           | 2.56                 | 2.38             | 2.51          | 2.48          |
| Selenium, total             | mg/L         | MAC=0.05  | <0.00050             | <0.00050         | <0.00050      | <0.00050      |
| Sodium, total               | mg/L         | AO<=200   | 11.5                 | 10.9             | 13.8          | 14.5          |
| Strontium, total            | mg/L         | 7         | 0.269                | 0.252            | 0.263         | 0.261         |
| Uranium, total              | mg/L         | MAC=0.02  | 0.00243              | 0.00229          | 0.00238       | 0.00231       |
| Zinc, total                 | mg/L         | AO<=5     | <0.0040              | 0.0061           | <0.0040       | <0.0040       |

MAC= Maximum Acceptable Concentration related to Health Concerns

AO = Aesthetic Objective related to Taste, Odor, Appearance

**Table 26.** Treated Water comprehensive analysis summary

## Pesticides and Herbicides

The scan presented here includes historically applied compounds as well as newly formulated spray compounds. As of July 2021, none of the scanned Pesticides or Herbicides have been identified in the Kelowna water drinking water system meet appreciable drinking water levels (Table 27).

| <b>CARO Analytical Services</b>  |       |         | POPLAR POINT<br>TREATED | ELDORADO<br>TREATED | KVR TREATED | SWICK ROAD<br>TREATED |
|----------------------------------|-------|---------|-------------------------|---------------------|-------------|-----------------------|
| Date Sampled                     |       |         | 26-Jul-2021             | 26-Jul-2021         | 26-Jul-2021 | 26-Jul-2021           |
| Parameter                        | Units | CDWQG   | Water                   | Water               | Water       | Water                 |
| <b>Organochlorine Pesticides</b> |       |         |                         |                     |             |                       |
| Aldrin                           | ug/L  |         | <0.006                  | <0.006              | <0.006      | <0.006                |
| alpha-BHC                        | ug/L  |         | <0.010                  | <0.010              | <0.010      | <0.010                |
| beta-BHC                         | ug/L  |         | <0.050                  | <0.050              | <0.050      | <0.050                |
| delta-BHC                        | ug/L  |         | <0.050                  | <0.050              | <0.050      | <0.050                |
| DDT, Total                       | ug/L  |         | <0.010                  | <0.010              | <0.010      | <0.010                |
| Dieldrin                         | ug/L  |         | <0.010                  | <0.010              | <0.010      | <0.010                |
| Endosulfan I + II                | ug/L  |         | <0.010                  | <0.010              | <0.010      | <0.010                |
| Endosulfan sulfate               | ug/L  |         | <0.050                  | <0.050              | <0.050      | <0.050                |
| Endrin aldehyde                  | ug/L  |         | <0.020                  | <0.020              | <0.020      | <0.020                |
| Endrin ketone                    | ug/L  |         | <0.020                  | <0.020              | <0.020      | <0.020                |
|                                  |       |         |                         |                     |             |                       |
| <b>Herbicides</b>                |       |         |                         |                     |             |                       |
| Bromacil                         | ug/L  |         | <0.100                  | <0.100              | <0.100      | <0.100                |
| Bromoxynil                       | ug/L  | MAC=5   | <0.20                   | <0.20               | <0.20       | <0.20                 |
| Butachlor                        | ug/L  |         | <0.020                  | <0.020              | <0.020      | <0.020                |
| Cyanazine                        | ug/L  |         | <0.10                   | <0.10               | <0.10       | <0.10                 |
| 2,4-D                            | ug/L  | MAC=100 | <0.10                   | <0.10               | <0.10       | <0.10                 |
| Dicamba                          | ug/L  | MAC=120 | <0.10                   | <0.10               | <0.10       | <0.10                 |
| Dinoseb                          | ug/L  |         | <0.10                   | <0.10               | <0.10       | <0.10                 |
| Diuron                           | ug/L  | MAC=150 | <0.200                  | <0.200              | <0.200      | <0.200                |
| MCPA                             | ug/L  | MAC=100 | <0.020                  | <0.020              | <0.020      | <0.020                |
| 2,4,5-T                          | ug/L  |         | <0.10                   | <0.10               | <0.10       | <0.10                 |
| Picloram                         | ug/L  | MAC=190 | <0.10                   | <0.10               | <0.10       | <0.10                 |

| CARO Analytical Services     |      |         | POPLAR POINT TREATED | ELDORADO TREATED | KVR TREATED | SWICK ROAD TREATED |
|------------------------------|------|---------|----------------------|------------------|-------------|--------------------|
| <b>Pesticides/Fungicides</b> |      |         | 26-Jul-2021          | 26-Jul-2021      | 26-Jul-2021 | 26-Jul-2021        |
| Alachlor                     | ug/L |         | <0.10                | <0.10            | <0.10       | <0.10              |
| Atrazine & Metabolites       | ug/L | MAC=5   | <0.10                | <0.10            | <0.10       | <0.10              |
| Azinphos-methyl              | ug/L | MAC=20  | <0.20                | <0.20            | <0.20       | <0.20              |
| Captan                       | ug/L |         | <0.100               | <0.100           | <0.100      | <0.100             |
| Chlordane (cis + trans)      | ug/L |         | <0.050               | <0.050           | <0.050      | <0.050             |
| Chlorothalonil               | ug/L |         | <0.050               | <0.050           | <0.050      | <0.050             |
| Chlorpyrifos                 | ug/L | MAC=90  | <0.010               | <0.010           | <0.010      | <0.010             |
| Deltamethrin                 | ug/L |         | <0.100               | <0.100           | <0.100      | <0.100             |
| Diazinon                     | ug/L | MAC=20  | <0.020               | <0.020           | <0.020      | <0.020             |
| Dichlorvos                   | ug/L |         | <0.10                | <0.10            | <0.10       | <0.10              |
| Diclofop-methyl              | ug/L | MAC=9   | <0.10                | <0.10            | <0.10       | <0.10              |
| Dimethoate                   | ug/L | MAC=20  | <0.200               | <0.200           | <0.200      | <0.200             |
| Disulfoton                   | ug/L |         | <0.100               | <0.100           | <0.100      | <0.100             |
| Endrin                       | ug/L |         | <0.020               | <0.020           | <0.020      | <0.020             |
| Fenchlorphos (Ronnel)        | ug/L |         | <0.100               | <0.100           | <0.100      | <0.100             |
| Heptachlor                   | ug/L |         | <0.010               | <0.010           | <0.010      | <0.010             |
| Heptachlor epoxide           | ug/L |         | <0.010               | <0.010           | <0.010      | <0.010             |
| Lindane                      | ug/L |         | <0.050               | <0.050           | <0.050      | <0.050             |
| Linuron                      | ug/L |         | <0.050               | <0.050           | <0.050      | <0.050             |
| Malathion                    | ug/L | MAC=190 | <0.10                | <0.10            | <0.10       | <0.10              |
| Methoxychlor                 | ug/L |         | <0.050               | <0.050           | <0.050      | <0.050             |
| Methyl parathion             | ug/L |         | <0.100               | <0.100           | <0.100      | <0.100             |
| Metolachlor                  | ug/L | MAC=50  | <0.10                | <0.10            | <0.10       | <0.10              |
| Metribuzin                   | ug/L | MAC=80  | <0.200               | <0.200           | <0.200      | <0.200             |
| Parathion                    | ug/L |         | <0.100               | <0.100           | <0.100      | <0.100             |
| Pentachloronitrobenzene      | ug/L |         | <0.100               | <0.100           | <0.100      | <0.100             |
| Permethrin                   | ug/L |         | <0.010               | <0.010           | <0.010      | <0.010             |
| Phorate                      | ug/L | MAC=20  | <0.10                | <0.10            | <0.10       | <0.10              |
| Prometon                     | ug/L |         | <0.300               | <0.300           | <0.300      | <0.300             |
| Prometryne                   | ug/L |         | <0.10                | <0.10            | <0.10       | <0.10              |
| Simazine                     | ug/L | MAC=10  | <0.200               | <0.200           | <0.200      | <0.200             |
| Sulfotep                     | ug/L |         | <0.100               | <0.100           | <0.100      | <0.100             |
| Tebuthiuron                  | ug/L |         | <0.200               | <0.200           | <0.200      | <0.200             |
| Temephos (Abate)             | ug/L |         | <0.500               | <0.500           | <0.500      | <0.500             |
| Terbufos                     | ug/L | MAC=1   | <0.10                | <0.10            | <0.10       | <0.10              |
| Triallate                    | ug/L |         | <0.10                | <0.10            | <0.10       | <0.10              |
| Trifluralin                  | ug/L | MAC=45  | <0.200               | <0.200           | <0.200      | <0.200             |

Table 27. Pesticide and Herbicide scans of treated water

## Radiological Parameters

There were minor detectable levels of Gross Alpha compounds (naturally occurring) and minor concentrations of Gross Beta compounds (artificially occurring), but well below the CDWQ guidelines (Table 28).

| SRC Analytical Services |            |       | POPLAR POINT<br>TREATED | ELDORADO<br>TREATED | CEDAR CREEK<br>TREATED | SWICK ROAD<br>TREATED |
|-------------------------|------------|-------|-------------------------|---------------------|------------------------|-----------------------|
| Date Sampled            |            |       | 26-Jul-2021             | 26-Jul-2021         | 26-Jul-2021            | 26-Jul-2021           |
| Parameter               | Guideline* | Units | Water                   | Water               | Water                  | Water                 |
| <b>Radiological</b>     |            |       |                         |                     |                        |                       |
| Gross Alpha             | <1         | Bq/L  | <0.09                   | <0.09               | 0.08                   | <0.08                 |
| Gross Beta              | <1         | Bq/L  | 0.15                    | <0.07               | 0.19                   | 0.15                  |

**Table 28.** Radiological scans of treated water

# Appendix D

## Water Distribution Water Quality Monitoring Parameters

# Distribution Water Quality Parameters

## Chlorine – Free

In order to maintain free chlorine residual throughout the distribution system, booster stations are equipped to inject additional sodium hypochlorite at strategic intervals and are sampled from point of source through to end of pipe in order to maintain an operational target of 0.2 mg/mL free chlorine residual throughout. These sites are monitored weekly and reported to IHA on a monthly basis. All minimal operating Chlorine residual concentrations were maintained in the City distribution system in with some operational challenges in the Swick system (Figure 36). The 5-year trend indicates fairly consistent decrease in free Chlorine residual throughout the City system distribution sourced from Poplar Point, Cedar, and Eldorado (Figure 37).

|             | Average (mg/L) | Minimum (mg/L) | Maximum (mg/L) | Number of Tests in 2022 |
|-------------|----------------|----------------|----------------|-------------------------|
| City System | 0.76           | 0.2            | 1.98           | 1067                    |
| Swick       | 0.41           | 0.1            | 1.42           | 88                      |

Table 29. Free Chlorine in distribution water system





Figure 36. Monthly average Free Chlorine in Distribution System





**Figure 37. 5-Year Average Free Chlorine in Distribution System**

## Total Coliform

Total Coliform and E. Coli. bacteria are monitored routinely at various points along the distribution system to ensure that no bacterial re-growth has occurred and that new bacteria has not been introduced through leaks or line breaks. To date, there has been no indication that there were detectable levels of Total Coliform or E. Coli. at any of the distribution sampling sites (Table 30 and 31).

|                    | Average<br>(MPN/100ml) | Minimum<br>(MPN/100ml) | Maximum<br>(MPN/100ml) | Guideline<br>(MPN/100ml) | Number of<br>Exceedances | Number of<br>Tests in 2022 |
|--------------------|------------------------|------------------------|------------------------|--------------------------|--------------------------|----------------------------|
| <b>City System</b> | <1.0                   | <1.0                   | <1.0                   | <1.0                     | <1.0                     | 1046                       |
| <b>Swick</b>       | <1.0                   | <1.0                   | <1.0                   | <1.0                     | <1.0                     | 87                         |

**Table 30. Total Coliform in distribution water system summary**

## E. Coli.

|                    | Average<br>(MPN/100<br>ml) | Minimum<br>(MPN/100ml) | Maximum<br>(MPN/100ml) | Guideline<br>(MPN/100ml) | Number of<br>Exceedances | Number of<br>Tests in 2022 |
|--------------------|----------------------------|------------------------|------------------------|--------------------------|--------------------------|----------------------------|
| <b>City System</b> | <1.0                       | <1.0                   | <1.0                   | <1.0                     | <1.0                     | 1046                       |
| <b>Swick</b>       | <1.0                       | <1.0                   | <1.0                   | <1.0                     | <1.0                     | 87                         |

**Table 31. E. Coli. in distribution water system summary**

Trihalomethanes

Trihalomethanes (THM) and Haloacetic acids (HAA) are produced during the relatively slow organic reaction that occur between free chlorine and naturally occurring organic precursors such as humic and fulvic acids. Samples are tested quarterly (Figure 38) and also reported as an annual average to demonstrate compliance with the 0.10 mg/L Canadian Drinking Water guideline requirements. TTHM concentrations in 2022 were on average higher than 2021, but shown a as marginal increase over the past 5 years. This is primarily a result of the extension of the distribution into remote areas within Southeast Kelowna (Figure 39).

|             | Average (mg/L) | Minimum (mg/L) | Maximum (mg/L) | Guideline (mg/L) | Number of Exceedances | Number of Tests in 2022 |
|-------------|----------------|----------------|----------------|------------------|-----------------------|-------------------------|
| City System | 0.0632         | 0.0224         | 0.1360         | <0.1             | 3                     | 31                      |
| Swick       | 0.0581         | 0.0216         | 0.087          | <0.1             | 0                     | 6                       |

Table 32. Summary of THM concentrations in the distribution water system




Figure 38. Quarterly TTHM in Distribution system




Figure 39. 5-year THM trend in Distribution Systems

Haloacetic Acids

Haloacetic acid, much like THM, is a part of a disinfection byproduct that has health guideline associated with them. There were no guideline exceedances above 0.8 mg/L at any of the sampling sites throughout 2022 (Table 33). The 5-year trend indicates a marginally decreasing concentration of HAA’s in the City system, but lower in non-flooding years (Figure 41).

|             | Average (mg/L) | Minimum (mg/L) | Maximum (mg/L) | Guideline (mg/L) | Number of Exceedances | Number of Tests in 2022 |
|-------------|----------------|----------------|----------------|------------------|-----------------------|-------------------------|
| City System | 0.0393         | 0.0158         | 0.0788         | <0.08            | 0                     | 31                      |
| Swick       | 0.0235         | 0.0125         | 0.0364         | <0.08            | 0                     | 6                       |

Table 33. Summary of HAA concentrations in the distribution water system




Figure 40. Quarterly Haloacetic Acids in Distribution Systems




Figure 41. 5-year Haloacetic Acid trends in Distribution Systems

## **Appendix E**

### Drainage and Beaches

## Drainage and Beaches

### Introduction

One of the largest water quality impacts to Okanagan Lake stems from upland water sources and storm water outfall discharges. The principal stormwater scenario is that the stormwater flows develop in response to local precipitation and carry a wide variety of pollutants such as sand, silt, dissolved metals, pesticides, nutrients, and fecal material. Additionally, exceptional events can occur in which a fuel or chemical spill enters the stormwater system.

In order to understand the relationship that these water sources have to the water quality at the City intakes, the COK has been comparing and overlaying water quality parameters from impactful creeks identified in the Source Water Assessment with the intake water quality. These insights help shape environmental planning and action in the event that trends, or threats are identified. The monitoring consists of routine creek sampling, supplemental creek monitoring in the event of elevated Turbidity at intakes to determine if a connection in events exist. Monitoring is also increased during substantial rain events, first flush storm system events in spring, and beach sampling for *E. Coli.* during the summer months.

### Creek Monthly Monitoring

The mouths of Brandt's, Mill, and Mission Creek are sampled a minimum of 5 times in one month (5/30) throughout the year, weather and conditions permitting. Turbidity and Bacterial trends are noted and communicated to the respective Utility groups to allow for operational adjustments or investigate possible storm-sanitary interconnect contamination.



Creek testing parameters include ammonia, chloride, true color, conductivity, dissolved oxygen, *E. coli*, pH, total suspended solids, temperature, and Turbidity and are graphically presented relative to a number of applicable water quality guidelines including:

- British Columbia Aquatic Water Quality Guidelines (BCAWQG)
- Canadian Drinking Water Quality guidelines (CDWQG) Aesthetic Objectives (AO)
- Canadian Council of the Ministry of Environment (CCME)
- Guidelines for Canadian Recreational Water Quality (GCRWQ)

Specific sampling sites listed in the figures can be found in the [Sampling Site](#) section of this Appendix.

Ammonia

Presence of high concentrations of Ammonia can indicate that sewage contamination may be present and coming from septic or sanitary leakage. For all major tributaries, the concentrations were below calculated CCME guidelines for freshwater. Brandt’s Creek had a notable uptick in Ammonia concentrations in 2022. Similarly, the annual average ammonia concentrations indicated an overage increase in ammonia at Brandt’s (Figure 43).




Figure 42. Monthly Ammonia average for creek samples




Figure 43. 8-Year Ammonia average for creek samples

Chloride

Presence of elevated Chloride concentrations is a potential indicator that dissolved road salt is contributing to discharge into creeks. Monthly data indicated a downward trend through freshet in all tributaries and all within Aesthetic objectives. The 8-year trend indicated that the flooding events of 2017 and 2018 had a very marginal effect on chloride concentrations relative to non-flooding years (Figure 45).




Figure 44. Monthly Chloride average for creek samples




Figure 44. 8-year Chloride average for creek samples



Color

Color in creeks is typically related to the volume of the water flow and the extent of upstream or in-stream bank / bed erosion occurring. The decomposition of naturally occurring organic materials in the bank and floating materials give the creek water its distinctive dark brown appearance and reduces the overall water clarity. The color concentrations tend to spike in in Mission and Mill creeks during times of freshet and subside during low flow seasons (Figure 46).




Figure 46. Monthly Color averages for creek samples




Figure 47. 8-Year Color average for creek samples

Conductivity

Conductivity concentrations, an indication of the amount of minerals in the water, trended lower through freshet with little evidence of impact of road salt application (Figure 48). The overall 8-year trend indicates that conductivity is increasing in the major tributaries and potentially influencing the overall conductivity in Okanagan Lake (Figure 49).




Figure 48. Monthly Conductivity averages for creek samples




Figure 49. 8-Year Conductivity average for creek samples

Dissolved Oxygen

Dissolved Oxygen concentration levels above 14 mg/L or below 2 mg/L have a detrimental effect on aquatic life and becomes more saturated in colder water as is demonstrated in the seasonal measurement (Figure 50). Tributaries tested indicate that the monthly average for dissolved oxygen never went below the CCME lower range limit while the 8-year averages show a marginal increasing trend (Figure 51).




Figure 50. Monthly Dissolved Oxygen average for creek samples




Figure 51. 8-year Dissolved Oxygen average for creek samples

E.coli.

The highest E. coli counts have typically been observed in Brandt’s creek with elevated counts in the fall and winter most likely due to lower flow, lack of water freezing in the winter, and an increase in waterfowl present (Figure 52). The dredging of Mill creek in 2018/2019 most likely related to the overall increasing trend in E.coli. counts over the past 8 years (Figure 53). The only creek regularly observed within the Recreational guidelines is Mission creek.




Figure 52. Monthly E. coli averages in creek samples




Figure 53. 8-year E.coli. average for creek samples

pH  
Freshet periods tends to historically have an acidify effect on water quality while the most alkaline periods are observed during colder seasons (Figure 54). The 8-year trend indicates a modest decrease in all three creeks in 2022 relative to the previous 3 years, but all still within the drinking water guidelines ((Figure 55).




Figure 54. Monthly pH averages for creek samples




Figure 55. 8-year pH average for creek samples

Total Suspended Solids (TSS)

As with Color and Turbidity, Total Suspended Material increased during the intense freshet and rain events that flushed sediment through the tributaries (Figure 56). The overall trend saw a general rebound in TSS concentrations over the flooding years of 2017 and 2018 (Figure 57).




Figure 56. Monthly TSS averages for creek samples




Figure 57. 8-year TSS average for creek samples

Turbidity

The monthly and year over year concentration patterns of Turbidity were closely linked to the concentration of Total Suspended Solids (Figures 56-59).




Figure 58. Monthly Turbidity averages for creek samples




Figure 59. 8-yearTurbidity averages for creek samples

Temperature

The monthly profile of each of the main tributaries was consistent with previous years, as is the annual average over the past 8 years (Figures 60-61).




Figure 60. Monthly Temperature average for creek samples




Figure 61. 8-year Temperature average for creek samples



Nitrates and Phosphates

Soluble nutrients and minerals carried through tributaries are one of the largest, consistent contributors of Nitrates and Phosphorus concentrations in OK lake. Monthly measurements do not indicate any elevated levels of nitrogen coinciding with freshet (Figure 62), but has been observed in a phosphorus spike in Mill and Brandt’s (Figure 63). As this is the third year of monitoring, longer term trends will be tracked moving forward.




Figure 62. Monthly Nitrate concentrations for creek samples




Figure 63. Monthly Phosphate concentrations for creek samples

Creek Testing during elevated Turbidity at Intakes

The mouths of Brandt’s Creek, Mill Creek, and Mission Creek are sampled when there is increased Turbidity in raw water quality. Turbidity concentrations at the drinking water intakes are typically 0.5 NTU or below, but increases in the spring when freshet occurs, and the lake is mixing. The intent of this tracking is to potentially correlate the contribution of creek Turbidity and *E. coli* concentrations to Turbidity at the Intakes and subsequent natural asset planning and restoration that could take place in the future to minimize these impacts. It also provides a predictive model to assess elevated risk and allow for operational treatment adjustments in preparation for such impacts.

Poplar Point Intake

Although Brandt’s Creek has the closest proximity to the Poplar Point intake, it’s relatively low flow and drainage into a designated wetland before entering the lake prevents it from having a significant impact. Mission and Mill creek turbidity seems to coincide with elevated turbidity at the Poplar Point intake (Figure 64, 65). Bear and Brandt’s did not appear to have a significant contribution to elevated counts during freshet.





Figure 64. Poplar Point Intake Turbidity relative to surrounding Tributary Turbidities during freshet




Figure 65. Poplar Point Intake E. coli relative to surrounding Tributary E. coli during freshet

Cedar Creek Intake

Historically, Mission Creek has proven to have the highest impact to water quality at the Cedar Creek intake due to the high volume of water and proximity, but is very much dependent on wind and current direction. There was an increase in Cedar Creek intake turbidity shortly after the large Mission creek turbidity spike. There was some correlation between the various creeks E. coli and Cedar E. coli (Figure 66, 67).




Figure 66. Cedar Creek Intake Turbidity relative to surrounding Tributary Turbidities during freshet




Figure 67. Cedar Creek Intake E. coli relative to surrounding Tributary E. coli during freshet

Eldorado Intake

Due to the relatively shallower depth, Eldorado has typically seen the highest impact from tributary water quality. Both Mission and Mill creeks have historically had the greatest influence, but 2022 measurements only indicated a marginal impact and did not appear to have a significant impact (Figure 68). E.coli counts remained low through the seasonal use of the intake, similar to the creeks (Figure 69).




Figure 68. Eldorado Intake Turbidity relative to surrounding Tributary Turbidities during freshet




Figure 69. Eldorado Intake E. coli relative to surrounding Tributary E. coli during freshet

Swick Intake

Varty creek has the closest proximity in relation to Swick, but the impact varies dramatically based on the overall volume and time span of the snowmelt in the lower snow shed. Other creeks in the area are considered seasonal as well and did not appear to have significant impact to the observed Turbidity or E.coli counts at the Swick intake (Figure 70, 71).




Figure 70. Swick Intake Turbidity relative to surrounding Tributary Turbidities during freshet




Figure 71. Swick Intake E. coli relative to surrounding Tributary E. coli during freshet

## First Flush and Rain Event Monitoring at Outfalls

First flush is defined as the first major rain or snow melt that would push significant material through the storm water system and eventually into Okanagan lake. Brandt's Creek and Mill Creek outfalls were monitored during the first flush and rain events of more than 5mm during March-October (Table 34-35). As expected, there was consistent trend of First Flush depositing the highest amount of Suspended Solids, Color, E. coli and Turbidity into the creeks relative to subsequent rain events. Conductivity, Chloride, and pH all tended to drop as a result of a dilution and buffering and acidity effect of the snow / rain water – which is consistent with previous years' trend.

| Brandt's Creek Outfall                   |  |   |   |                                |   |                               |
|--|--|---|---|--------------------------------|---|-------------------------------|
| Parameter                                | Brandt's Creek at Brant Ave, Dec 14, 2021 Pre-Rainfall | Rain Event on Snow Event ~9mm, Jan 13, 2022 | Brandt's Creek at Brant Ave, May 26, 2022, Pre-Rainfall | Rain Event ~14mm, Jun 13, 2022 | Brandt's Creek at Brant Ave, Oct 25, 2022, Pre-Rainfall | Rain Event ~14mm, Nov 4, 2022 |
| Ammonia as NH <sub>3</sub> -N (mg/l)     | 0.18   | 0.84  | 0.05  | 0                              | 0.08  | 0.07                          |
| Chloride (mg/l)                          | 148  | 440   | 83  | 8                              | 58  | 58                            |
| True Colour (Pt-Co Units)                | 133  | 98  | 43  | 258                            | 70  | 78                            |
| Conductivity (µs/cm <sup>2</sup> )       | 1955   | 1959  | 1896  | 174                            | 1439  | 333                           |
| Dissolved Oxygen (mg/l)                  | 9.69   | 9.31  | 8.88  | 8.12                           | 9.44  | 9.85                          |
| E. coli (MPN/100ml)                      | 988  | 85  | 146   | 1860                           | 250   | 278                           |
| Nitrate as NO <sub>3</sub> -N (mg/l)     | 3.18   | 0.7   | 3.07  | 0.09                           | 2.32  | 0.98                          |
| o-Phosphate as PO <sub>4</sub> -P (mg/l) | 0.12   | 0.14  | 0.14  | 0.13                           | 0.12  | 0.03                          |
| pH                                       | 8.07   | 7.14  | 8.08  | 7.7                            | 8.02  | 7.52                          |
| Total Suspended Solids (mg/l)            | 44   | 17  | 10  | 41                             | 24  | 8                             |
| Temperature (°C)                         | 5.9  | 5.6   | 13.9  | 13.9                           | 11.1  | 10                            |
| Turbidity (NTU)                          | 37.1   | 19.8  | 6.56  | 43.9                           | 17.7  | 8.88                          |

Table 34. Water Quality at Brandt's creek during rainfall events

| Mill Creek Outfall                       |   |  |   |                                |  |                               |
|--|---|--|---|--------------------------------|--|-------------------------------|
| Parameter                                | Mill Creek at Hardy St. Nov 24, 2021 Pre-Rainfall | Rain Event on Snow Event ~9mm Jan 13, 2022 | Mill Creek at Hardy St. May 18, 2022 Pre-Rainfall | Rain Event ~14mm, Jun 13, 2022 | Mill Creek at Hardy St. Oct 19, 2022, Pre-Rainfall | Rain Event ~14mm, Nov 4, 2022 |
| Ammonia as NH <sub>3</sub> -N (mg/l)     | 0.04  | 0.63                                       | 0.03  | 0                              | 0.02   | 0.25                          |
| Chloride (mg/l)                          | 66  | 313  | 12  | 17                             | 25   | 17                            |
| True Colour (Pt-Co Units)                | 56  | 116  | 133   | 292                            | 61   | 71                            |
| Conductivity (µs/cm <sup>2</sup> )       | 776.3   | 4675                                       | 187.6   | 154                            | 383.1  | 539.2                         |
| Dissolved Oxygen (mg/l)                  | 12.39   | 11.46                                      | 10.55   | 8.27                           | 10.75  | 10.02                         |
| E. coli (MPN/100ml)                      | 114.5   | 355  | 61.3  | 1607                           | 275.5  | 132                           |
| Nitrate as NO <sub>3</sub> -N (mg/l)     | 1.71  | 1.3  | 0.35  | 0.39                           | 0.73   | 0.41                          |
| o-Phosphate as PO <sub>4</sub> -P (mg/l) | 0   | 0.07                                       | 0.03  | 0.29                           | 0.03   | 0.19                          |
| pH                                       | 8.07  | 7.32                                       | 7.13  | 7.57                           | 8.04   | 7.55                          |
| Total Suspended Solids (mg/l)            | 13  | 39   | 22  | 41                             | 20.7   | 4                             |
| Temperature (°C)                         | 5.4   | 4.4  | 11.4  | 15.9                           | 9.3  | 6.5                           |
| Turbidity (NTU)                          | 9   | 31.2                                       | 12.1  | 48.5                           | 8.73   | 8.03                          |

Table 35. Water quality at Mill creek during rainfall events

## Fascieux Creek Rain Event Sampling

Fascieux Creek is a typical storm collection creek within the Utility boundary that is monitored at multiple locations during rain events to potentially identify contamination connected with raw sewage. Along with various chemical parameters, E. coli. is the primary indicator for storm / sanitary interconnection as it is not naturally occurring and carries a significant health risk. Further investigation is required in the event that E. Coli. counts are in excess of 25,000 MPN/100mL. Chemical and Biological profiles and trends recorded were similar to that noted at the Brandt's and Mill Creek outfalls (Tables 34-35). The tested samples did not indicate any significant increase in E. coli. concentrations, which indicates that there are no current interconnection issues with sanitary for this outfall system.

| Fascieux Creek at Gordon Drive           |                                       |                                 |                                    |              |
|--|---------------------------------------|---------------------------------|------------------------------------|--------------|
| Parameter                                | Rain on Snow Event ~9mm, Jan 13, 2022 | Rain Event ~14mm, June 13, 2022 | Rain Event ~14mm, November 4, 2022 | 2022 Average |
| Ammonia NH <sub>3</sub> -N (mg/l)        | 0.75                                  | 0.00                            | 0.03                               | 0.26         |
| Chloride (mg/l)                          | 202                                   | 17                              | 30                                 | 83           |
| True Colour (Pt-Co Units)                | 120                                   | 122                             | 63                                 | 102          |
| Conductivity (µs/cm <sup>2</sup> )       | 1066                                  | 273                             | 552                                | 630          |
| Dissolved Oxygen (mg/l)                  | 7.64                                  | 5.84                            | 5.31                               | 6.26         |
| E. coli (MPN/100ml)                      | 135                                   | 1145                            | 1860                               | 660          |
| Nitrate as NO <sub>3</sub> -N (mg/l)     | 0.85                                  | 0.43                            | 1.00                               | 0.76         |
| o-Phosphate as PO <sub>4</sub> -P (mg/l) | 0.06                                  | 0.08                            | 0.07                               | 0.07         |
| pH (No Units)                            | 7.54                                  | 7.57                            | 7.46                               | 7.52         |
| Total Suspended Solids (mg/l)            | 14                                    | 15                              | 0                                  | 10           |
| Temperature (°C)                         | 5.3                                   | 15.9                            | 6.9                                | 9.4          |
| Turbidity (NTU)                          | 19.6                                  | 15.3                            | 5.3                                | 13.4         |

Table 36. Water quality test results of Fascieux Creek at Gordon during rain events

| Fascieux Creek at Gosnell Road           |   |                                    |                                       |              |
|--|---|------------------------------------|---------------------------------------|--------------|
| Parameter                                | Rain on Snow<br>Event ~9mm,<br>Jan 13, 2022 | Rain Event ~14mm,<br>June 13, 2022 | Rain Event ~14mm,<br>November 4, 2022 | 2022 Average |
| Ammonia NH <sub>3</sub> -N (mg/l)        | 0.44  | 0.00                               | 0.00                                  | 0.15         |
| Chloride (mg/l)                          | 88  | 17                                 | 26                                    | 44           |
| True Colour (Pt-Co Units)                | 47  | 67                                 | 55                                    | 56           |
| Conductivity (µs/cm <sup>2</sup> )       | 904   | 289                                | 410                                   | 535          |
| Dissolved Oxygen (mg/l)                  | 7.94  | 5.59                               | 6.14                                  | 6.56         |
| E. coli (MPN/100ml)                      | 448   | 1670                               | 5475                                  | 1600         |
| Nitrate as NO <sub>3</sub> -N (mg/l)     | 0.81  | 0.16                               | 0.53                                  | 0.50         |
| o-Phosphate as PO <sub>4</sub> -P (mg/l) | 0.08  | 0.22                               | 0.13                                  | 0.14         |
| pH (No Units)                            | 7.44  | 7.51                               | 7.60                                  | 7.52         |
| Total Suspended Solids (mg/l)            | 11  | 9                                  | 1                                     | 7            |
| Temperature (°C)                         | 5.6   | 15.3                               | 4.3                                   | 8.4          |
| Turbidity (NTU)                          | 9.5   | 7.3                                | 3.1                                   | 6.6          |

**Table 37.** Water quality test results of Fascieux Creek at Gosnell during rain events

| Fascieux Creek at Watt Road                 |   |                                    |                                       |              |
|---|---|------------------------------------|---------------------------------------|--------------|
| Parameter                                   | Rain on Snow<br>Event ~9mm, Jan<br>13, 2022 | Rain Event ~14mm,<br>June 13, 2022 | Rain Event ~14mm,<br>November 4, 2022 | 2022 Average |
| Ammonia NH <sub>3</sub> -N (mg/l)           | 0.97  | 0.06                               | 1.39                                  | 0.81         |
| Chloride (mg/l)                             | 187   | 35                                 | 50                                    | 91           |
| True Colour (Pt-Co Units)                   | 72  | 76                                 | 80                                    | 76           |
| Conductivity (µs/cm <sup>2</sup> )          | 1094  | 513                                | 681                                   | 763          |
| Dissolved Oxygen (mg/l)                     | 8.97  | 5.62                               | 6.37                                  | 6.99         |
| E. coli (MPN/100ml)                         | 1291  | 557                                | 909                                   | 868          |
| Nitrate as NO <sub>3</sub> -N (mg/l)        | 0.93  | 0.74                               | 0.28                                  | 0.65         |
| o-Phosphate as PO <sub>4</sub> -P<br>(mg/l) | 0.05  | 0.09                               | 0.10                                  | 0.08         |
| pH (No Units)                               | 7.47  | 7.38                               | 7.36                                  | 7.40         |
| Total Suspended Solids<br>(mg/l)            | 55  | 14                                 | 13                                    | 27           |
| Temperature (°C)                            | 6.1   | 15.6                               | 8.5                                   | 10.1         |
| Turbidity (NTU)                             | 28.0  | 11.5                               | 12.8                                  | 17.4         |

**Table 38.** Water quality test results of Fascieux Creek at Watt during rain events

## Beach Sampling for *E. coli*

City of Kelowna beaches were sampled at eleven sites once a week from June to September of 2021. The beaches sampled were City Park (2 sites), Gyro Beach Park (2 sites), Rotary Beach Park (2 sites), Sarson's Beach Park (2 sites), Strathcona Park (1 site), and Waterfront Park (2 sites). The graphs indicate the geometric mean for each site relative to the geometric mean guideline, which is the primary determining factor when beaches need further testing or required water quality notification for swimmers. Rotary consistently had the highest *E. coli* counts of any beach (Figure 72, 73).






Figure 72. E. Coli. test results at north Kelowna beaches




Figure 73. E. Coli. test results at south Kelowna beaches

## Tributary and Beach Sampling Sites

The creeks sampled are Brandt's Creek, Mill Creek, Mission Creek, and Fascieux Creek. The main sample site on Brandt's Creek is near the mouth of Brandt's Creek located in Rotary Marsh Wetland on Sunset Drive (Figure 62). The other sample site on Brandt's Creek is a 750mm outfall pipe located on Gordon Drive and Weddell Place which is sampled for first flush as well as during rain events of 7mm or more. The main sample site on Mill Creek is located near the mouth at the end of Lake Avenue (Figure 62). The other sample site on Mill Creek is a 1075mm outfall pipe located on Enterprise Way and Hardy Street which is sampled for first flush as well as during rain events of 5mm or more. The main sample site located on Mission Creek is near the mouth and is accessed by Bluebird Road (Figure 62). Fascieux Creek has three sampling site locations: Gordon Drive between KLO Road and Bothe Road, Gosnell Road and Quesnel Road, and at the end of Watt Road. Beach sites are located between lower Mission and Knox Mountain foreshore.



**Figure 74.** Kelowna Beach and Creek sample sites